

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 765 Located on map 155 Received: 1-2-76 Form GW 8 Form GW 9

1) OWNER: Person having well drilled Jack Anderson (Name) Address Huntsville Texas (Street or RFD) (City) (State) Landowner Same (Name) Address Same (Street or RFD) (City) (State)

2) LOCATION OF WELL: County Walker Labor League Abstract No. NW 1/4 NE 1/4 SW 1/4 SE 1/4 of Section Block No. Survey 16 miles in NW direction from Huntsville (Town) Sketch map of well location with distances from adjacent section or survey lines, and to landmarks, roads, and creeks. County Road 5 miles well 11 miles to Huntsville NORTH

3) TYPE OF WORK (Check): New Well [x] Deepening [] Reconditioning [] Plugging [] 4) PROPOSED USE (Check): Domestic [x] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] 5) TYPE OF WELL (Check): Rotary [x] Driven [] Dug [] Cable [] Jetted [] Bored []

6) WELL LOG: Diameter of hole 4 in. Depth drilled 589 ft. Depth of completed well 589 ft. Date drilled 1-2-76 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows: 0-280 Blue Shale, 280-400 Brown Shale, 400-570 Green Shale, 570-589 Sand.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. (Use reverse side if necessary)

7) COMPLETION (Check): Straight wall [x] Gravel packed [] Other [] Under reamed [] Open hole []

8) WATER LEVEL: Static level 40 ft. below land surface Date 1-2-70 Artesian pressure lbs. per square inch Date

9) CASING: Type: old [] New [x] Steel [x] Plastic [] Other [] Cemented from ft. to ft.

10) SCREEN: Type Plastic Screen Perforated [x] Slotted []

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Gage. Row: 4, 0, 589, 10 1/2

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Slot size. Row: 2 1/2, 574, 589, 10 gm

11) WELL TESTS: Was a pump test made? [] Yes [x] No If yes by whom? Yield: gpm with ft. drawdown after hrs Bailer test gpm with ft. drawdown after hrs Artesian flow gpm Date Temperature of water Was a chemical analysis made? [] Yes [x] No Did any strata contain undesirable water? [] Yes [x] No Type of water? Fresh depth of strata 589

12) PUMP DATA: Manufacturer's Name Type H.P. Designed pumping rate gpm [] gph [] Type power unit Depth to bowls, cylinder, jet, etc., ft. below land surface.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME J.B. BRADFORD (Type or Print) Water Well Drillers Registration No. 765 Address 303 N McIVER (Street or RFD) MADISONVILLE (City) TEXAS (State) (Signed) J.B. Bradford (Water Well Driller) J.B. Bradford & Son (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

8

RECEIVED
OCT 30 1970
Central Records
Texas Water Development Board

RECEIVED
AUG 31 1970
TEXAS WATER
DEVELOPMENT BOARD