

ATTENTION OWNER: Confidentiality
 Privilege Notice on on reverse side
 of Well Owner's copy (pink)

State of Texas
WELL REPORT

Texas Water Well Drillers Advisory Council
 MC 177
 P.O. Box 13087
 Austin, TX 78711-3087
 512-239-0530

1) OWNER Peter Pathier (Name) ADDRESS P.O. Box 612, Huntsville, TX 77342 (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL Walker County 7771 Scales Ranch Road (Street, RFD or other) (City) (State) (Zip) Huntsville, TX 60-10-7 GRID #

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
 4) PROPOSED USE (Check): Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
 If Public Supply well, were plans submitted to the TNRCC? Yes No

6) WELL LOG:
 Date Drilling: Started 11 19 99 Completed 11 19 99
 DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
<u>6 3/4"</u>	<u>Surface</u>	<u>714</u>

 7) DRILLING METHOD (Check): Driven Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted Other
 5) 30-4585
95-5031

8) Borehole Completion (Check): Open Hole Straight Wall
 Underreamed Gravel Packed Other
 If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
<u>4</u>	<u>N</u>	<u>Plastic</u>	<u>0</u>	<u>699</u>	<u>.237</u>
<u>2 1/2</u>	<u>N</u>	<u>Underbar Cut Screen</u>	<u>699</u>	<u>714</u>	<u>.12</u>
		<u>Well Supplies Mfg. Houston, TX.</u>			

9) CEMENTING DATA [Rule 338.44(1)]
 Cemented from 0 ft. to 15 ft. No. of sacks used _____
 _____ ft. to _____ ft. No. of sacks used _____
 Method used S&K pump
 Cemented by S&K Drilling Co.
 Distance to septic system field lines or other concentrated contamination 200 ft.
 Method of verification of above distance measured

13) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
 Depth to pump bowls, cylinder, jet, etc., 380 ft.

14) WELL TESTS:
 Type test: Pump Bailer Jetted Estimated
 Yield: _____ gpm with _____ ft. drawdown after _____ hrs.

15) WATER QUALITY:
 Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
 Type of water? _____ Depth of strata _____
 Was a chemical analysis made? Yes No

10) SURFACE COMPLETION
 Specified Surface Slab Installed [Rule 338.44(2)(A)]
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
 Pitless Adapter Used [Rule 338.44(3)(b)]
 Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL:
 Static level 59' ft. below land surface Date 11-99
 Artesian flow _____ gpm. Date _____

12) PACKERS:

Type	Depth
<u>4" Formation packer</u>	<u>360'</u>

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmission.

COMPANY NAME S&K Drilling Co. (Type or print) WELL DRILLER'S LICENSE NO. MAY 18 2000 - WI
 ADDRESS Rt 1 - Box 78 (Street or RFD) Navasota, TX (City) 77868 (State) (Zip)
 (Signed) [Signature] (Licensed Well Driller) (Signed) [Signature] (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

ATTENTION OWNER: Confidentiality <i>Privilege Notice on Reverse Side</i>		State of Texas WELL REPORT		Texas Water Well Drillers Advisory Council P.O. Box 13087 Austin, TX 78711-3087 512-371-6299	
1) OWNER <u>Carl Storey</u> (Name)		ADDRESS <u>17603 Macranpha Spring Tx 77379</u> (Street or RFD) (City) (State) (Zip)			
2) ADDRESS OF WELL: County <u>Walker</u>		<u>Scales Ranch Rd</u> (Street or RFD)		<u>Bedias Tx</u> (City) (State) (Zip) STATE WELL # _____	
3) TYPE OF WORK (Check): <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Deepening <input type="checkbox"/> Reconditioning <input type="checkbox"/> Plugging		4) PROPOSED USE (Check): <input type="checkbox"/> Monitor <input type="checkbox"/> Environmental Soil Boring <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Industrial <input type="checkbox"/> Irrigation <input type="checkbox"/> Injection <input type="checkbox"/> Public Supply <input type="checkbox"/> De-watering <input type="checkbox"/> Testwell If Public Supply well, were plans submitted to the TNRCC? <input type="checkbox"/> Yes <input type="checkbox"/> No			5)
6) WELL LOG: Date Drilling: Started <u>4-25</u> 19 <u>96</u> Completed <u>4-30</u> 19 <u>96</u>		DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) <u>6.5</u> Surface <u>471</u>		7) DRILLING METHOD (Check): <input type="checkbox"/> Driven <input type="checkbox"/> Air Rotary <input checked="" type="checkbox"/> Mud Rotary <input type="checkbox"/> Bored <input type="checkbox"/> Air Hammer <input type="checkbox"/> Cable Tool <input type="checkbox"/> Jetted <input type="checkbox"/> Other _____	
From (ft.) To (ft.) Description and color of formation material		8) Borehole Completion (Check): <input checked="" type="checkbox"/> Open Hole <input type="checkbox"/> Straight Wall <input type="checkbox"/> Underreamed <input type="checkbox"/> Gravel Packed <input type="checkbox"/> Other _____ If Gravel Packed give interval ... from _____ ft. to _____ ft.			
0 1 top bit soil		CASING, BLANK PIPE, AND WELL SCREEN DATA: Dia. (in.) New or Used Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial Setting (ft.) From To Gage Casting Screen 4 N PVC casing 1.5 459 2.5 N Stainless steel 459 469 10			
1 30 br. cl.					
30 72 bl. cl.					
72 81 lign. & br. cl.					
81 93 lign.					
93 136 bl. cl.					
136 141 sa.					
141 151 sa. & cl.					
151 166 sa.					
166 170 cl.					
170 181 sa. st.		9) CEMENTING DATA [Rule 338.44(1)] Cemented from <u>1.5</u> ft. to <u>12</u> ft. No. of sacks used <u>2</u> <u>371</u> ft. to <u>471</u> ft. No. of sacks used <u>7</u> Method used <u>pressure</u> Cemented by <u>Henry Lee</u> Distance to septic system field lines _____ ft. Method of verification of above distance <u>no septic</u>			
181 201 sa cl. st.					
201 236 bl. cl.					
236 271 sa.					
271 371 bl. cl.		10) SURFACE COMPLETION <input type="checkbox"/> Specified Surface Slab Installed [Rule 338.44(2)(A)] <input type="checkbox"/> Specified Steel Sleeve Installed [Rule 338.44(3)(A)] <input checked="" type="checkbox"/> Pitless Adapter Used [Rule 338.44(3)(b)] <input type="checkbox"/> Approved Alternative Procedure Used [Rule 338.71]			
(Use reverse side if necessary)		11) WATER LEVEL: Static level <u>127</u> ft. below land surface Date <u>4-30-96</u> Artesian flow _____ gpm. Date _____			
13) TYPE PUMP: <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Cylinder <input type="checkbox"/> Other _____ Depth to pump bowls, cylinder, jet, etc., _____ ft.		12) PACKERS: Type Depth <u>2.5" RxR Rubber Packer 453'</u>			
14) WELL TESTS: Type test: <input type="checkbox"/> Pump <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Jetted <input checked="" type="checkbox"/> Estimated Yield: <u>10</u> gpm with _____ ft. drawdown after _____ hrs.		15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable constituents? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water? <u>good</u> Depth of strata <u>13</u> Was a chemical analysis made? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.					
COMPANY NAME <u>Holly Water Wells</u> (Type or print)		WELL DRILLER'S LICENSE NO. <u>2221W</u>			
ADDRESS <u>607 Hwy 19</u> (Street or RFD)		<u>Huntsville</u> (City)		<u>Tx 77340</u> (State) (Zip)	
(Signed) <u>Henry Lee</u> (Licensed Well Driller)		(Signed) _____ (Registered Driller Trainee)			

Please attach electric log, chemical analysis, and other pertinent information, if available.

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-10-7A Located on map yes Received: 7/2 dlr

1) OWNER: Person having well drilled Dr. WALTON Address (Name) (Street or RFD) (City) (State) Landowner SAME Address Same (Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER, miles in direction from (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*

30° 47' X 95° 50'

North

(Use reverse side if necessary)

Give legal location with distances and directions from adjacent sections or survey lines.

Labor League

Block Survey

Abstract No.

(NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging

4) PROPOSED USE (Check): Domestic Industrial Municipal Irrigation Test Well Other

5) TYPE OF WELL (Check): Rotary Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 in. Depth drilled 406 ft. Depth of completed well 406 ft. Date drilled 4-9-72 All measurements made from 1 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-33 Sup. Clay 222-232 Sand, 33-56 Clay & Rock 235-250 br. Sand, 56-78 Lignite 250-347 Clay, 78-101 Shale 347-369 Clay w/ brks, 92-95 Sand 369-389 Sandy Shale, 101-123 Clay 389-403 - Sand, 123-146 Shale & br. Sand 403-406 Clay, 146-168 Sandy Shale, 168-190 Clay, 190-212 Clay & Shale, 212-222 Clay

9) Casing: Type: Old New Steel Plastic Other Cemented from 0 ft. to 380 ft.

Table with 4 columns: Diameter (inches), Setting From (ft.), Setting To (ft.), Gage. Row: 4, 0, 380

10) SCREEN: Type PVC Perforated Slotted

Table with 4 columns: Diameter (inches), Setting From (ft.), Setting To (ft.), Slot Size. Row: 2 1/2", 382, 402, .016

20 on 34

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom?

Yield: gpm with ft. drawdown after hrs.

Bailer test: gpm with ft. drawdown after hrs.

Artesian flow: gpm

Temperature of water

8) WATER LEVEL: Static level 66 ft. below land surface Date 4-9-72 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 210' ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No

Did any strata contain undesirable water? Yes No

Type of water? depth of strata

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME J.S. (Pat) FAIKENBURY Water Well Drillers Registration No. 81

ADDRESS P.O. Box 668 Navasota Texas 77868

(Signed) J.S. (Pat) FALKENBURY FAIKENBURY DRILLING CO. (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED
JAN 18 1972
Central Records
Texas Water Development Board

RECEIVED
AUG 18 1972
Texas Water Development Board

#1 Walker

236

Please use black ink. Send original copy by certified mail to the Texas Water Commission P.O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Paul Lewis (Name) Address 1819 Grand Valley Houston, Texas 77090 (Street or RFD) (City) (State) (Zip)
2) LOCATION OF WELL: County Walker 18 miles in W direction from Huntsville (N.E., S.W., etc.) (Town)

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map.

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Monitor Public Supply Irrigation Test Well Injection Other
5) DRILLING METHOD (Check): Driven Mud Rotary Air Hammer Jetted Bored Air Rotary Cable Tool Other

6) WELL LOG: Date Drilling: 4-4 19 89 Started 4-7 19 89 Completed 4-7 19 89
DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6.5 Surface 714
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval . . . from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include soil, clay, sand, and limestone layers.

RECEIVED MAY 22 1989

TEXAS WATER COMMISSION

(Use reverse side if necessary)

15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? Yes No If yes, submit "REPORT OF UNDESIRABLE WATER" 30 ft Type of water? Good Depth of strata 30 ft Was a chemical analysis made? Yes No
14) WELL TESTS: Type Test: Pump Bailer Jetted Estimated Yield: 20 gpm with ft. drawdown after hrs.

I here by certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 12 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME HOLLY WATER WELLS Water Well Driller's License No. 2026
ADDRESS 607 Hwy 19 Huntsville, Texas 77340 (Street or RFD) (City) (State) (Zip)
(Signed) [Signature] (Licensed Water Well Driller) (Signed) [Signature] (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. For TWC use only Well No. 60-10-7 Located on map

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Texas Water Commission are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a Commission copy, shall include the name, mailing address, and telephone number of the Board and the Commission. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

