

#1 WALKER

Please use black ink. Send original copy by certified mail to the Texas Water Commission P.O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Gator Lake Ranch Attn. Norman Adams Address P O Box 7011 Houston, TX 77248
2) LOCATION OF WELL: County WALKER 7 miles in NW direction from HUNTSVILLE

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map.

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Monitor Public Supply Irrigation Test Well Injection Other
5) DRILLING METHOD (Check): Mud Rotary Air Hammer Jetted Bored Air Rotary Cable Tool Other

6) WELL LOG: Date Drilling 05/08 1987 Started 05/09 1987 Completed 05/09 1987
DIAMETER OF HOLE: Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 102
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial, Setting (ft.), Gage Casing Screen. Rows include Top soil, Brown clay, Blue clay, Lignite, Blue clay, Sand.

9) CEMENTING DATA [Rule 319.44(b)] Cemented from 3 ft. to 80 ft. No. of Sacks Used 7 Method used Pressure Cemented by Holly Water Well Service

10) SURFACE COMPLETION Specified Surface Slab Installed Pitless Adapter Used Approved Alternative Procedure Used

11) WATER LEVEL: Static level 20 ft. below land surface Date 5-10-87 Artesian flow gpm. Date

12) PACKERS: Rubber Type Depth 77

13) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 70 ft.

14) WELL TESTS: Type Test: Pump Bailer Jetted Estimated Yield: 25 gpm with ft. drawdown after hrs.

RECEIVED AUG 19 1987

TEXAS WATER COMMISSION

I here by certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221 ADDRESS 607 Hwy. 19 Huntsville, TX 77340

(Signed) [Signature] (Licensed Water Well Driller) (Signed) [Signature] (Registered Driller Trainee) For TWC use only Well No. 60-11-8 Located on map

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Texas Water Commission are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:




“Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a Commission copy, shall include the name, mailing address, and telephone number of the Board and the Commission. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.



LEGEND

	INTERSTATE HIGHWAY
	FEDERAL HIGHWAY
	STATE HIGHWAY
	COUNTY ROAD
	LOCAL ROAD
	RAILROAD
	AIRWAY
	CANAL
	WATERWAY
	LAKE/RESERVOIR
	RIVER
	STREAM
	MARSH
	SWAMP
	FOREST
	PARK
	CEMETERY
	SCHOOL
	CHURCH
	POST OFFICE
	GAS STATION
	TELEPHONE EXCHANGE
	POWER LINE
	WATER LINE
	SEWER LINE
	GAS LINE
	ELECTRIC LINE
	TELEPHONE LINE
	FIRE HYDRANT
	FIRE ALARM BOX
	FIRE STATION
	POLICE STATION
	COURT HOUSE
	CITY HALL
	SCHOOL BUILDING
	CHURCH BUILDING
	POST OFFICE BUILDING
	GAS STATION BUILDING
	TELEPHONE EXCHANGE BUILDING
	POWER PLANT
	WATER TREATMENT PLANT
	SEWER TREATMENT PLANT
	GAS PLANT
	ELECTRIC PLANT
	TELEPHONE PLANT
	FIRE STATION BUILDING
	POLICE STATION BUILDING
	COURT HOUSE BUILDING
	CITY HALL BUILDING
	SCHOOL BUILDING
	CHURCH BUILDING
	POST OFFICE BUILDING
	GAS STATION BUILDING
	TELEPHONE EXCHANGE BUILDING
	POWER PLANT BUILDING
	WATER TREATMENT PLANT BUILDING
	SEWER TREATMENT PLANT BUILDING
	GAS PLANT BUILDING
	ELECTRIC PLANT BUILDING
	TELEPHONE PLANT BUILDING




KEY TO COUNTIES

Copies of this map are available for public use at a nominal charge from the State Department of Highways and Public Transportation, 1000 North Ross Street, Austin, Texas 78701.

GENERAL HIGHWAY MAP WALKER COUNTY TEXAS

PREPARED BY THE
STATE DEPARTMENT OF HIGHWAYS
AND PUBLIC TRANSPORTATION
TRANSPORTATION PLANNING DIVISION
IN COOPERATION WITH THE
U.S. DEPARTMENT OF TRANSPORTATION
FEDERAL HIGHWAY ADMINISTRATION



1970 CENSUS FIGURES
HIGHWAYS RENAMED TO MARCH 1, 1978
POSSIBLE PROJECTIONS NORTH AMERICAN DRIVE
BASED ON U.S. COAST AND GEODETIC SURVEY AND U.S. GEODETIC SURVEY
APPROXIMATE ROAD TRANSITS

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas
WATER WELL REPORT

For TDWR use only
Well No. 60-11-8E
Located on map YES
Received: TH

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER MR WESLEY WILLIAMSON (Name) Address Rt 1 Box 307 HUNTSVILLE, TEXAS 77341 (Street or RFD) (City) (State) (Zip)
2) LOCATION OF WELL:
County WALKER 12 miles in NW direction from HUNTSVILLE (N.E., S.W., etc.) (Town)

Legal description:
Section No. _____ Block No. _____ Township _____
Abstract No. _____ Survey Name _____
Distance and direction from two intersecting section or survey lines _____
 See attached map. map on 60-22-7E

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check):
 Domestic Industrial Public Supply Irrigation Test Well Other _____
5) DRILLING METHOD (Check):
 Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other _____

6) WELL LOG:
Date drilled 6-27-79
DIAMETER OF HOLE
Dia. (in.) From (ft.) To (ft.)
6 1/2 Surface 310
7) BOREHOLE COMPLETION:
 Open Hole Straight Wall Underreamed
 Gravel Packed Other _____
If Gravel Packed give interval . . . from _____ ft. to _____ ft.

From (ft.)	To (ft.)	Description and color of formation material	8) CASING, BLANK PIPE, AND WELL SCREEN DATA:					
			Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.)		Gage Casing Screen
						From	To	
0	6	BROWN CLAY						
6	22	SAND STONE						
22	24	SAND						
34	68	BLUE CLAY			PLUGGED			
68	77	SAND						
77	104	BLUE CLAY						
104	107	ROCK						
107	152	BLUE CLAY						
152	170	SAND						
170	217	BLUE CLAY						
217	221	(SOFT LIGNITE)						
221	285	BLUE CLAY						
285	310	SAND						

9) WATER LEVEL:
Static level _____ ft. below land surface Date _____
Artesian flow _____ gpm. Date _____

10) PACKERS: Type Depth
CEMENT 150' 100'
25' 0'

11) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet, etc., _____ ft.

12) WELL TESTS:
 Type Test: Pump Bailer Jetted Estimated
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.

13) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable water? Yes No
If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata _____
Was a chemical analysis made? Yes No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 901
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State) (Zip)
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

DEPT. OF
WATER RESOURCES
OCT 24 1979
RECEIVED

RECEIVED
MAR 19 80
CR/TDWE

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas
WATER WELL REPORT

For TDWR use only
Well No. 60-11-8D
Located on map YES
Received: TH

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER MR DAVID BUTLER (Name) Address Box 5016 HUNTSVILLE TEXAS 77367 (Street or RFD) (City) (State) (Zip)
2) LOCATION OF WELL:
County WALKER miles in 10 direction from N W (N.E., S.W., etc.) HUNTSVILLE (Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.
 Legal description:
Section No. _____ Block No. _____ Township _____
Abstract No. _____ Survey Name _____
Distance and direction from two intersecting section or survey lines _____
 See attached map. Map on 60-22-7E

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check):
 Domestic Industrial Public Supply Irrigation Test Well Other _____
5) DRILLING METHOD (Check):
 Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other _____

6) WELL LOG:
Date drilled 9-24-79
DIAMETER OF HOLE
Dia. (in.) From (ft.) To (ft.)
6 1/2 Surface _____
7) BOREHOLE COMPLETION:
 Open Hole Straight Wall Underreamed
 Gravel Packed Other _____
If Gravel Packed give interval . . . from _____ ft. to _____ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.) From	To	Gage Casing Screen
0	22	BROWN CLAY						
22	52	SAND & ROCK						
52	163	BLUE CLAY						
163	169	SAND	4	N	PLASTIC	325	71	SC 40
169	289	BLUE CLAY						
289	295	SAND						
295	325	BLUE CLAY	2 1/2	N	STAINLESS STEEL	327	337	#70
325	337	SAND						

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:
CEMENTING DATA
Cemented from 325 ft. to 275 ft.
Method used PRESSURE
Cemented by F.A. HOLLY (Company or Individual)

9) WATER LEVEL:
Static level 90 ft. below land surface Date 9-24-79
Artesian flow _____ gpm. Date _____

10) PACKERS:
Type LEAD Depth 320

11) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet, etc., 300 ft.

12) WELL TESTS:
 Type Test: Pump Bailer Jetted Estimated
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.

13) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable water? Yes No
If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? GOOD Depth of strata 12
Was a chemical analysis made? Yes No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State) (Zip)
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

DEPT. OF
WATER RESOURCES
OCT 24 1979
RECEIVED

RECEIVED

MAR 19 '80

CR./TDWR

Send original copy by certified mail* to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-11-8C Located on map Received: 77 yes

1) OWNER:
 Person having well drilled GWEN BATES Address Huntsville TEX
 (Name) (Street or RFD) (City) (State)
 Landowner SAME Address _____
 (Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:
 County WALKER, B miles in NW direction from Huntsville
 (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*
 Give legal location with distances and directions from adjacent sections or survey lines.
 Labor _____ League _____
 Block _____ Survey _____
 Abstract No. _____
 (NW $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$) of Section _____

X well site FM 1791 North X Huntsville

(Use reverse side if necessary)

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging

4) PROPOSED USE (Check):
 Domestic Industrial Municipal Irrigation Test Well Other

5) TYPE OF WELL (Check):
 Rotary Driven Dug Cable Jetted Bored

6) WELL LOG:
 Diameter of hole 6 3/4 in. Depth drilled 140 ft. Depth of completed well 140 ft. Date drilled 5-19-77
 All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	2	top soil
2	20	SAND (BROWN)
20	45	SAND (BLUE)
45	70	SAND (BROWN)
70	100	SAND (GREY)
100	140	SAND (BLUE)

9) CASING:
 Type: Old New Steel Plastic Other _____
 Cemented from 0 ft. to 0 ft.
 Diameter (inches) 4" Setting From (ft.) 0 To (ft.) 130 Gage sch 40

10) SCREEN:
 Type plastic sch 40
 Perforated Blotted
 Diameter (inches) 4" Setting From (ft.) 130 To (ft.) 140 Slot Size 010

7) COMPLETION (Check):
 Straight wall Gravel packed Other _____
 Under reamed Open Hole

11) WELL TESTS:
 Was a pump test made? Yes No If yes, by whom? _____
 Yield: 10 gpm with 10 ft. drawdown after 1 hrs.
 Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
 Artesian flow 7 gph gpm
 Temperature of water _____

8) WATER LEVEL:
 Static level _____ ft. below land surface Date 5-20-77
 Artesian pressure _____ lbs. per square inch Date _____
 Depth to pump bowls, cylinder, jet, etc., 100 ft. below land surface.

12) WATER QUALITY:
 Was a chemical analysis made? Yes No
 Did any strata contain undesirable water? Yes No
 Type of water? soft depth of strata 40'

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME JAMES L. GRAHAM Water Well Drillers Registration No. 1781
 (Type or Print)
 ADDRESS Rt 2 Box 276 Willis TEX 77358
 (Street or RFD) (City) (State)
 (Signed) James L. Graham AAA WATER WELLS
 (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED
JUN 1 1977
TEXAS WATER
DEVELOPMENT BOARD

JUL 28 1977

Central Records
Texas Water Development Board

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only
Well No. 60-11-8B
Located on map yes
Received: 77
dlr

1) OWNER:
Person having well drilled PETE ALLBRITTON (Name) Address RT 5 Box 97-1 HUNTSVILLE, TEXAS (Street or RFD) (City) (State)
Landowner ASCENSION CHEMICAL INC. (Name) Address HUNTSVILLE TEXAS (Street or RFD) (City) (State)

2) LOCATION OF WELL:
County WALKER, 9 miles in E direction from HUNTSVILLE (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*

or Give legal location with distances and directions from adjacent sections or survey lines.

HY 190 DODGE WELL North FM 405 HUNTSVILLE

Labor _____ League _____
Block _____ Survey _____
Abstract No. _____
(NW $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$) of Section _____

(Use reverse side if necessary)

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging

4) PROPOSED USE (Check):
 Domestic Industrial Municipal Irrigation Test Well Other

5) TYPE OF WELL (Check):
 Rotary Driven Dug Cable Jetted Bored

6) WELL LOG:
Diameter of hole 6 $\frac{3}{4}$ in. Depth drilled 296 ft. Depth of completed well 296 ft. Date drilled 12-21-76
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material	9) Casing: Type: Old _____ New _____ Steel _____ Plastic _____ Other _____
0	130	SAND	Cemented from <u>286</u> ft. to <u>200</u> ft.
130	282	WHITE CLAY	Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Gage _____
282	296	SAND	<u>4</u> <u>286</u> <u>+1</u> <u>SCH 40</u>
(Use reverse side if necessary)			10) SCREEN: Type <u>STAINLESS STEEL</u> Perforated _____ Slotted _____
			Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Slot Size _____
			<u>2$\frac{1}{2}$</u> <u>286</u> <u>296</u> <u># 10</u>

7) COMPLETION (Check):
 Straight wall Gravel packed Other Under reamed Open Hole

8) WATER LEVEL:
Static level 175 ft. below land surface Date 12-27-76
Artesian pressure _____ lbs. per square inch Date _____
Depth to pump bowls, cylinder, jet, etc., 260 ft. below land surface.

11) WELL TESTS:
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.
Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
Artesian flow _____ gpm
Temperature of water _____

12) WATER QUALITY:
Was a chemical analysis made? Yes _____ No _____
Did any strata contain undesirable water? Yes _____ No _____
Type of water? GOOD depth of strata 14 FT

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State)
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY Co. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.


2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.



RECEIVED
JAN - 6 1977
TEXAS WATER
DEVELOPMENT BOARD

STATE OF TEXAS
DEPARTMENT OF WATER RESOURCES
DALLAS, TEXAS

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. Located on map Received: Form GW 8 Form GW 9

1) OWNER: Person having well drilled Gary Hardy Address Huntville Texas Landowner Same Address Same

2) LOCATION OF WELL: County Walker Labor League Abstract No. NW 1/4 NE 1/4 SW 1/4 SE 1/4 of Section Block No. Survey miles in W direction from Coffee Prairie (Town) Sketch map of well location with distances from adjacent section or survey lines, and to landmarks, roads, and creeks. Includes a hand-drawn map showing the well location relative to FM 1696, 1 mile, and landmarks like Madisonville and Crabbs Prairie.

3) TYPE OF WORK (Check): New Well [X] Deepening [] Reconditioning [] Plugging [] 4) PROPOSED USE (Check): Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] 5) TYPE OF WELL (Check): Rotary [X] Driven [] Dug [] Cable [] Jetted [] Bored []

6) WELL LOG: Diameter of hole 4 in. Depth drilled 530 ft. Depth of completed well 530 ft. Date drilled 6-1-70 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-320 Brown shale, 320-500 Soapstone shale, 500-530 Sand.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. (Use reverse side if necessary)

7) COMPLETION (Check): Straight wall [X] Gravel packed [] Other [] Under reamed [] Open hole []

8) WATER LEVEL: Static level 30 ft. below land surface Date 6-1-70 Artesian pressure lbs. per square inch Date

9) CASING: Type: old [] New [X] Steel [] Plastic [] Other [] Cemented from ft. to ft.

10) SCREEN: Type Plastic Screen Perforated [X] Slotted []

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Gage. Row: 4, 0, 505, 10 1/2

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Slot size. Row: 2 1/2, 510, 530, 15 gr.

11) WELL TESTS: Was a pump test made? Yes [X] No [] If yes by whom? J.B. Bradford Yield: 15 gpm with 40 ft. drawdown after 12 hrs Bailer test gpm with ft. drawdown after hrs Artesian flow gpm Date Temperature of water Was a chemical analysis made? Yes [] No [X] Did any strata contain undesirable water? Yes [] No [X] Type of water? Good depth of strata 530

12) PUMP DATA: Manufacturer's Name Ruth Benz Type Sub. Pump H.P. 1 Designed pumping rate 900 gpm gph [X] Type power unit Depth to bowls, cylinder, jet, etc., 105 ft. below land surface.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME J.B. BRADFORD (Type or Print) Water Well Drillers Registration No. 765 Address 303 N. McIVER (Street or RFD) MADISONVILLE (City) TEXAS (State) (Signed) J.B. Bradford (Water Well Driller) J.B. Bradford + Son (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

TEXAS WATER
DRAINAGE BOARD

AUG 31 1970

RECEIVED

RECEIVED
OCT 20 1970
Central Inquiries
Texas Water Board