

ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse Side

State of Texas  
WELL REPORT

Texas Water Well Drillers Advisory Council  
P.O. Box 13087  
Austin, TX 78711-3087  
512-239-0530

1) OWNER Mr. Hurtz ADDRESS 71-C Julia Justice Huntsville TX. 77320  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County Walker Julia Justice Rd Huntsville TX 77320 Long. Lat. GRID # 60-13-5  
(Street, RFD or other) (City) (State) (Zip)

3) TYPE OF WORK (Check):  New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  Monitor  Environmental Soil Boding  Domestic  Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG: Date Drilling: Started 5-2 20 00 5-3 20 00  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6.75 Surface 156  
7) DRILLING METHOD (Check):  Driven  Air Rotary  Mud Rotary  Bored  Air Hammer  Cable Tool  Jetted  Other

From (ft.)	To (ft.)	Description and color of formation material
0	2	Top bit soil
2	12	Sa.st.
12	23	Calr.
23	32	Sa.
32	42	Sa.st.
42	48	Sa.
48	58	Sa.st.
58	66	Bl.
66	70	Sa.
70	82	Mily.bl.
82	102	H. wh & bl.
102	142	Bl.
142	156	Sand

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other  
If Gravel Packed give interval ... from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC Casing	-1.5	143	
2.5	N	PVC Screen	146	156	#8

9) CEMENTING DATA [Rule 338.44(1)]  
Cemented from -1.5 ft. to 143 ft. No. of sacks used 9  
Method used Pressure  
Cemented by HWW  
Distance to septic system field lines or other concentrated contamination \_\_\_\_\_ ft.  
Method of verification of above distance \_\_\_\_\_

13) TYPE PUMP:  Turbine  Jet  Submersible  Cylinder  Other  
Depth to pump bowls, cylinder, jet, etc., 120 ft.

10) SURFACE COMPLETION  
 Specified Surface Slab Installed [Rule 338.44(2)(A)]  
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]  
 Pitless Adapter Used [Rule 338.44(3)(b)]  
 Approved Alternative Procedure Used [Rule 338.71]

14) WELL TESTS:  
Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: 12 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

11) WATER LEVEL  
Static Level 39 ft. below land surface Date \_\_\_\_\_  
Artesian flow \_\_\_\_\_ gpm Date \_\_\_\_\_

15) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata, 14  
Was a chemical analysis made?  Yes  No

12) PACKERS: Type Depth  
2 - 2.5" Rubber Packers RxR 138' & 139'

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Wells  
(Type or print)

WELL DRILLER'S LICENSE NO. 2221W

ADDRESS 2928 SH 19  
(Street or RFD)

Huntsville TX 77320  
(City) (State) (Zip)

(Signed) [Signature]  
(Licensed Well Driller)

(Signed) \_\_\_\_\_  
(Registered Driller - Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

EMP # \_\_\_\_\_ (Registered Driller - Trainee)  
DESC CO \_\_\_\_\_  
JUN 12 2000  
COMMENT \_\_\_\_\_

Main body of the document containing several paragraphs of text. The text is extremely faint and largely illegible due to low contrast and scan quality. Some words and phrases are barely discernible.

ATTENTION OWNER: Confidentiality  
Privilege Notice on reverse side  
of Well Owner's copy (pink)

# State of Texas WELL REPORT

Texas Department of Licensing & Regulation  
P.O. Box 12157  
Austin, TX 78711  
512-463-7880

1) OWNER Hazel Brown (Name) ADDRESS 2980 Hwy 19 Hometown TX 77340 (Street or RFD) (City) (State) (Zip)  
 2) ADDRESS OF WELL'S LOCATION: County Walker Co. 2980 Hwy 19 Hometown TX 77340 Long. \_\_\_\_\_ Lat. \_\_\_\_\_  
 (Street, RFD or other) (City) (State) (Zip) Grid # 60-13-5

3) TYPE OF WORK (Check):  New Well  Deepening  Reconditioning  Plugging  
 4) PROPOSED USE (Check):  Monitor  Environmental Soil Boring  Domestic  Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
 If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG: Date Drilling: \_\_\_\_\_  
 Started 9-17-1999 Completed 9-20-1999  
 DIAMETER OF HOLE  

Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	10'
6 3/4"	10'	180'
3 7/8"	180'	189'

 7) DRILLING METHOD (Check):  Driven  Air Rotary  Mud Rotary  Bored  Air Hammer  Cable Tool  Jetted  Other \_\_\_\_\_

From (ft.)	To (ft.)	Description and color of formation material
0-4	clay	98-105 Sandy shale
4-21	clay	105-108 shale
21-34	clay	108-109 Rock
34-37	Sand	109-126 shale
37-63	shale	126-144 shale
63-73	Sand	144-147 Rock
73-78	shale	147-167 shale
78-80	Rock	167-176 shale
80-82	Rock	176-178 Rock
82-88	shale	178-189 Sand
88-92	Sand	
92-98	shale	

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other \_\_\_\_\_  
 If Gravel Packed give interval from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC	0	180'	*40
2	N	PVC	173'	179'	*40
2	N	PVC Screen	179'	189'	*8

13)  Well plugged within 48 hours  
 Casing left in well: \_\_\_\_\_ Cement/bentonite placed in well: \_\_\_\_\_ Sacks used: \_\_\_\_\_  

From (ft)	To (ft)	From (ft)	To (ft)

9) CEMENTING DATA  
 Cemented from 180' ft. to 80' ft. No. of sacks used 5  
0 ft. to 10 ft. No. of sacks used 6  
 Method used pressure  
 Cemented by Richard McKee  
 Distance to septic system field lines or other concentrated contamination 175'.  
 Method of verification of above distance Tape

14) TYPE PUMP:  Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
 Depth to pump bowls, cylinder, jet, etc., 140 ft.

10) SURFACE COMPLETION  
 Specified Surface Slab Installed  
 Specified Steel Sleeve Installed  
 Pitless Adapter Used  
 Approved Alternative Procedure Used

15) WELL TESTS:  
 Type test:  Pump  Bailer  Jetted  Estimated  
 Yield: 40 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

11) WATER LEVEL:  
 Static level 66' ft. below land surface Date 9-20-99  
 Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

16) WATER QUALITY:  
 Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
 Type of water? good Depth of strata 11'  
 Was a chemical analysis made?  Yes  No

12) PACKERS: Rubber Type K Depth 173'

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Gray's Water Well (Type or print) WELL DRILLER'S LICENSE NO. 2011 WPK  
 ADDRESS P.O. Box 1788 LEID (Street or RFD) (City) Taney (State) Tx (Zip) 75862  
 (Signed) Vernon Gray (Licensed Well Driller) (Signed) Richard McKee (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

COMMENT



# State of Texas WELL REPORT

Texas Department of Licensing & Regulation  
P.O. Box 12157  
Austin, TX 78711  
512-463-7880

1) OWNER Donald Merrell ADDRESS 123 Wood Farm Rd. Huntsville Tx 77340  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL'S LOCATION: County Walker 123 Wood Farm Rd. Huntsville Tx 77340 Long. \_\_\_\_\_ Lat. \_\_\_\_\_  
(Street, RFD or other) (City) (State) (Zip) Grid # 60-13-5

3) TYPE OF WORK (Check):  
 New Well  Deepening  
 Reconditioning  Plugging

(4) PROPOSED USE (Check):  Monitor  Environmental Soil Boring  Domestic  
 Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG:  
Date Drilling:  
Started 8-24 1999  
Completed 8-26 1999

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
10"	Surface	10'
6 3/4	10'	150'
3 7/8	150'	163

7) DRILLING METHOD (Check):  Driven  
 Air Rotary  Mud Rotary  Bored  
 Air Hammer  Cable Tool  Jetted  
 Other \_\_\_\_\_

From (ft.)	To (ft.)	Description and color of formation material
		0-1 Top Soil
		1-9 Clay
		9-16 Sand
		16-42 clay
		42-63 shale
		63-66 Rock
		66-102 Shale
		102-105 Rocks
		105-126 shale
		126-146 Shale
		146-163 Sand

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**CASING, BLANK PIPE, AND WELL SCREEN DATA:**

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casing Screen
			From	To	
4	N	PVC	0	150'	#40
2	N	PVC Blank	142'	143'	#40
2	N	PVC Screen	143'	163'	#10

9) CEMENTING DATA  
Cemented from 150 ft. to 0 ft. No. of sacks used 5  
0 ft. to 10 ft. No. of sacks used 6  
Method used pressure  
Cemented by Richard McKee  
Distance to septic system field lines or other concentrated contamination N/A ft.  
Method of verification of above distance None

13)  Well plugged within 48 hours

Casing left in well:		Cement/bentonite placed in well:		Sacks used:
From (ft)	To (ft)	From (ft)	To (ft)	

14) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 120 ft.

15) WELL TESTS:  
Type test:  Pump  Bailer  Jetted  Estimated  
Yield: 60 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

16) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? good Depth of strata 17'  
Was a chemical analysis made?  Yes  No

10) SURFACE COMPLETION  
 Specified Surface Slab Installed  
 Specified Steel Sleeve Installed  
 Pitless Adapter Used  
 Approved Alternative Procedure Used

11) WATER LEVEL:  
Static level 75' ft. below land surface Date 8-26-99  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

12) PACKERS: Rubber Type K Depth 142'

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Gray's Water Well Service WELL DRILLER'S LICENSE NO. 2011 WPK  
(Type or print) (SEQ #)  
ADDRESS P.O. Box 1788 Trinity Texas 75862  
(Street or RFD) (City) (State) (Zip)  
(Signed) Vernon Gray JUN 05 2000 (Signed) Richard McKee  
(Licensed Well Driller) (DESC CO) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.



# 40 WALKER

Please use black ink. Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER James E. Taylor Address Rt. 3 Box 610-F Huntsville, TX 77340
2) LOCATION OF WELL: County WALKER 6 miles in NE direction from HUNTSVILLE

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines...
Legal description: Section No. Block No. Township
Abstract No. Survey Name
Distance and direction from two intersecting section or survey lines

See attached map. map on 60-13-4d

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging
4) PROPOSED USE (Check): Domestic, Industrial, Public Supply, Irrigation, Test Well, Other
5) DRILLING METHOD (Check): Mud Rotary, Air Hammer, Driven, Bored, Air Rotary, Cable Tool, Jetted, Other

6) WELL LOG: Date drilled 6-27-85
DIAMETER OF HOLE: Dia. (in.) From (ft.) To (ft.)
6 1/2 Surface 152
7) BOREHOLE COMPLETION: Open Hole, Straight Wall, Underreamed, Gravel Packed, Other
If Gravel Packed give interval ... from ... ft. to ... ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial, Setting (ft.) From, To, Gage Casing Screen. Rows include Top soil, White clay, Rock, Sand and Rock streaks, Sand streaks, Meally clay, Rock, Meally clay, Sand.

9) CEMENTING DATA [Rule 319.44(b)]
Cemented from 132 ft. to 32 ft.
0 ft. to 10 ft.
Method used Pressure
Cemented by Henry Lee

10) SURFACE COMPLETION
Specified Surface Slab Installed [Rule 319.44(c)]
Pitless Adapter Used [Rule 319.44(d)]
Approved Alternative Procedure Used [Rule 319.71]

11) WATER LEVEL:
Static level ... ft. below land surface Date
Artesian flow ... gpm. Date

RECEIVED AUG 26 1985

12) PACKERS: Type Depth
Lead L 128

13) TYPE PUMP: Turbine, Jet, Submersible, Cylinder, Other
Depth to pump bowls, cylinder, jet, etc., ... ft.

14) WELL TESTS: Type Test: Pump, Bailer, Jetted, Estimated
Yield: 30 gpm with ... ft. drawdown after ... hrs.

15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? Yes No
If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? Good Depth of strata 54 Ft.
Was a chemical analysis made? Yes No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 12 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221
ADDRESS Rt. 11 Box 607 Huntsville, TX 77340
(Signed) [Signature] (Signed) [Signature]

Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 60-13-5W Located on map Yes C.F.S.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the department, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a department copy, shall include the name, mailing address, and telephone number of the Board and the department. The well log required herein shall at the request in writing to the department, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

STATE OF CALIFORNIA  
DEPARTMENT OF WATER RESOURCES  
WATER WELL DRILLERS BOARD  
1000 N. GARDEN AVENUE  
SACRAMENTO, CALIFORNIA 95833  
(916) 227-2300

Please use black ink.  
Send original copy by  
certified mail to the  
Texas Water Commission  
P.O. Box 13087  
Austin, Texas 78711

State of Texas  
WATER WELL REPORT

Texas Water Well Drillers Board  
P. O. Box 13087  
Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Frank Moten Address 2222 Isabella Houston Tx 77004  
(Name) (Street or RFD) (City) (State) (Zip)

2) LOCATION OF WELL: County Walker 9 miles in NE direction from Huntsville  
(N.E., S.W., etc.) (Town)

Legal description:  
Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.  
Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_  
 See attached map. 60-13-9

3) TYPE OF WORK (Check):  
 New Well  Deepening  
 Reconditioning  Plugging

4) PROPOSED USE (Check):  
 Domestic  Industrial  Monitor  Public Supply  
 Irrigation  Test Well  Injection  Other \_\_\_\_\_

5) DRILLING METHOD (Check):  Driven  
 Mud Rotary  Air Hammer  Jetted  Bored  
 Air Rotary  Cable Tool  Other \_\_\_\_\_

6) WELL LOG:  
Date Drilling:  
Started 3/31 19 86  
Completed 4/1 19 86

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
<u>6 1/2</u>	Surface	<u>192</u>

7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material
0-2		Top soil
2-24		Caliche
24-42		White clay
42-57		Sand
57-67		Sandy clay
67-127		Brown clay
127-142		Blue clay
142-146		Sand
146-182		Blue clay
182-190		Sand
190-192		Blue clay

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casing Screen
			From	To	
4	N	Plastic	-1 1/2	178	40
2 1/2	N	Plastic undercut	190	180	#8

9) CEMENTING DATA [Rule 319.44(b)]  
Cemented from 178 ft. to 78 ft. No. of Sacks Used 6  
10 ft. to 0 ft. No. of Sacks Used 1  
Method used Pressure  
Cemented by Holly Water Well Service

10) SURFACE COMPLETION  
 Specified Surface Slab Installed [Rule 319.44(c)]  
 Pitless Adapter Used [Rule 319.44(d)]  
 Approved Alternative Procedure Used [Rule 319.71]

11) WATER LEVEL:  
Static level 60 ft. below land surface Date 4/2/86  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

12) PACKERS: Type Depth  
Lead

13) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 180 ft.

15) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata 8  
Was a chemical analysis made?  Yes  No

14) WELL TESTS:  
Type Test:  Pump  Bailor  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.


I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 12 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221  
(Type or Print)

ADDRESS Rt. 11 Box 607 Huntsville TX 77340  
(Street or RFD) (City) (State) (Zip)

(Signed) [Signature] (Signed) \_\_\_\_\_  
(Licensed Water Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. For TWC use Well No. 60-13-5 Located on map \_\_\_\_\_



**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Texas Water Commission are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a Commission copy, shall include the name, mailing address, and telephone number of the Board and the Commission. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

WALKER ✓

#103

Please use black ink. Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Lonnie Granville Address 4110 Yellowstone Houston, TX 77021
2) LOCATION OF WELL: County Walker 9 miles in NE direction from HUNTSVILLE

Legal description: Section No. Block No. Township
Abstract No. Survey Name
Distance and direction from two intersecting section or survey lines
See attached map. 60-11-9

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging
4) PROPOSED USE (Check): Domestic, Industrial, Public Supply, Irrigation, Test Well, Other
5) DRILLING METHOD (Check): Mud Rotary, Air Hammer, Driven, Bored, Air Rotary, Cable Tool, Jetted, Other

6) WELL LOG: Date drilled 8-16-85
DIAMETER OF HOLE: Dia. (in.) From (ft.) To (ft.)
7) BOREHOLE COMPLETION: Open Hole, Straight Wall, Underreamed, Gravel Packed, Other

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.), Gage Casing Screen

9) CEMENTING DATA [Rule 319.44(b)]
Cemented from 178 ft. to 78 ft.
10 ft. to 0 ft.
Method used Pressure
Cemented by Henry Lee

10) SURFACE COMPLETION
Specified Surface Slab Installed [Rule 319.44(c)]
Pitless Adapter Used [Rule 319.44(d)]
Approved Alternative Procedure Used [Rule 319.71]

11) WATER LEVEL:
Static level 56 ft. below land surface
Artesian flow gpm.

12) PACKERS: Type L Depth 163

13) TYPE PUMP: Turbine, Jet, Submersible, Cylinder, Other
Depth to pump bowls, cylinder, jet, etc., 160 ft.

14) WELL TESTS: Type Test: Pump, Bailer, Jetted, Estimated
Yield: 30 gpm with ft. drawdown after hrs.

I here by certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221
ADDRESS Route 11 Box 607 Huntsville, TX 77340

(Signed) [Signature] (Registered Driller Trainee)
Please attach electric log, chemical analysis, and other pertinent information, if available.

For TDWR use only Well No. 60-13-5 Located on map

RECEIVED OCT 22 1985

TEXAS WATER COMMISSION

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the department, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a department copy, shall include the name, mailing address, and telephone number of the Board and the department. The well log required herein shall at the request in writing to the department, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

Walker #3

Please use black ink, Send original copy by certified mail to the Texas Water Commission P.O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER R.E. HABLE Address P.O. BOX 650 CORSICANA, TX. 75110
2) LOCATION OF WELL: County Walker 7 miles in N direction from Huntsville

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map. on 60-11-8

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Monitor Public Supply Irrigation Test Well Injection Other
5) DRILLING METHOD (Check): Mud Rotary Air Hammer Jetted Bored Air Rotary Cable Tool Other

6) WELL LOG: Date Drilling Started 06/08/87 Completed 06/08/87
DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 228
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval . . . from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include Top soil, Calichie Rock, Brown clay, Blue clay, Sand streaks, etc.

9) CEMENTING DATA [Rule 319.44(b)] Cemented from 165 ft. to 65 ft. No. of Sacks Used 6 Method used Pressure Cemented by Holly Water Wells Service

10) SURFACE COMPLETION Specified Surface Slab Installed Pitless Adapter Used Approved Alternative Procedure Used

11) WATER LEVEL: Static level 80 ft. below land surface Date 06/09/87 Artesian flow gpm. Date

12) PACKERS: Type Rubber Depth 2" 158

13) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 155 ft.

14) WELL TESTS: Type Test: Pump Bailer Jetted Estimated Yield: 30 gpm with ft. drawdown after hrs.

RECEIVED AUG 19 1987

TEXAS WATER COMMISSION (Use reverse side if necessary)

15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? Yes No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water? Depth of strata 15 Was a chemical analysis made? Yes No

I here by certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2221/2026

ADDRESS 607 Hwy.19 Huntsville, TX. 77340

(Signed) [Signature] (Licensed Water Well Driller) (Signed) [Signature] (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. For TWC use only Well No. 80-13-5 Located on map

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Texas Water Commission are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 30 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a Commission copy, shall include the name, mailing address, and telephone number of the Board and the Commission. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TDWR use only  
Well No. 60-13-5U  
Located on map YES  
Received: TH

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER STEVE HANLON (Name) Address 207 UNIVERSITY HUNTSVILLE TEXAS 77340 (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL: County WALKER 5 miles in 5 direction from RIVERSIDE (Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.

Legal description: Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

See attached map. Map on 60-19-4H

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 10-25-79  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6 1/2 Surface 164  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	8) CASING, BLANK PIPE, AND WELL SCREEN DATA:					
			Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.) From To	Gage Casing Screen	
<u>0</u>	<u>22</u>	<u>SANDY SOIL</u>						
<u>22</u>	<u>32</u>	<u>SAND</u>						
<u>32</u>	<u>150</u>	<u>BLUE CLAY</u>						
<u>150</u>	<u>164</u>	<u>SAND</u>	<u>4</u>	<u>N</u>	<u>PLASTIC</u>	<u>154</u>	<u>+1</u>	<u>5 3/4</u>
			<u>2 1/2</u>	<u>N</u>	<u>STAINLESS STEEL</u>	<u>164</u>	<u>-164</u>	<u>#8</u>

CEMENTING DATA  
Cemented from 154 ft. to 100 ft.  
Method used PRESSURE  
Cemented by E.A. HOLLY  
(Company or Individual)

9) WATER LEVEL:  
Static level 10 ft. below land surface Date 10-25-79  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type Depth  
LEAD 149

11) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 120 ft.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata 14  
Was a chemical analysis made?  Yes  No

12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 (Street or RFD) RIVERSIDE (City) TEXAS (State) 77367 (Zip)  
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

RECEIVED  
SEP 17 '80  
C. W. ADAMS

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

Texas Dept. of Water Resources

RECEIVED  
MAY 7 1980

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TDWR use only  
Well No. 60-13-5T  
Located on map YES  
Received: TH

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER MRS KATE ROWE (Name) Address 13000 HIGH RD HOUSTON, TEX. 77040 (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL: County WALKER 5 miles in S direction from RIVERSIDE (Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.  
 Legal description: Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

See attached map. map on 60-22-7E

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 8-23-79  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6 3/4 Surface 200  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.) From	To	Gage Casing Screen
0	69	WHITE SAND						
69	91	BLUE CLAY						
91	94	SAND						
94	190	BLUE CLAY			<u>4" N PLASTIC</u>	<u>190 + 1</u>	<u>50040</u>	
190	200	SAND						
			<u>2 3/8</u>	<u>N</u>	<u>STAINLESS STEEL</u>	<u>190</u>	<u>200</u>	<u>#10</u>

CEMENTING DATA  
Cemented from 190 ft. to 140 ft.  
Method used PRESSURE  
Cemented by F.A. HOLLY CO (Company or Individual)

9) WATER LEVEL: Static level 68 ft. below land surface Date 8-23-79  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type LEAD Depth 185

11) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 160 ft.

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? GOOD Depth of strata 10  
Was a chemical analysis made?  Yes  No  
12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 (Street or RFD) RIVERSIDE (City) TEXAS (State) 77367 (Zip)  
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

DEPT. OF  
WATER RESOURCES  
OCT 24 1979  
RECEIVED

RECEIVED

MAR 19 '80

CR/TDWR


Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only  
Well No. 60-13-511  
Located on map yes  
Received: 77  
JR

1) OWNER:  
Person having well drilled MR WILL DAVIS JR (Name) Address Box 143 (Street or RFD) RIVERSIDE, TEXAS (City) (State)  
Landowner SAME (Name) Address \_\_\_\_\_ (Street or RFD) \_\_\_\_\_ (City) (State)

2) LOCATION OF WELL:  
County WALKER, 3 miles in S direction from RIVERSIDE, TEXAS (N.E., S.W., etc.) (Town)  
Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\*  
  
Give legal location with distances and directions from adjacent sections or survey lines.  
Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW¼ NE¼ SW¼ SE¼) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging

4) PROPOSED USE (Check):  
 Domestic  Industrial  Municipal  Irrigation  Test Well  Other

5) TYPE OF WELL (Check):  
 Rotary  Driven  Dug  Cable  Jetted  Bored

6) WELL LOG:  
Diameter of hole 6 1/2 in. Depth drilled 190 ft. Depth of completed well 190 ft. Date drilled 4-7-77  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	58	WHITE CLAY
58	102	SANDY BLUE CLAY
102	183	WHITE CLAY
183	186	SAND
186	190	SAND BLUE CLAY

9) CASING:  
Type: Old \_\_\_\_\_ New \_\_\_\_\_ Steel \_\_\_\_\_ Plastic \_\_\_\_\_ Other \_\_\_\_\_  
Cemented from 180 ft. to 100 ft.  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
4 180 +1 SGH 40

10) SCREEN:  
Type STAINLESS STEEL  
Perforated \_\_\_\_\_ Slotted \_\_\_\_\_  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Slot Size \_\_\_\_\_  
2 1/2 190 190 # 8

7) COMPLETION (Check):  
 Straight wall  Gravel packed  Other \_\_\_\_\_  
 Under reamed  Open Hole

11) WELL TESTS:  
Was a pump test made? Yes  No  If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_

8) WATER LEVEL:  
Static level 62 ft. below land surface Date 4-7-77  
Artesian pressure \_\_\_\_\_ lbs. per square inch. Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 160 ft. below land surface.

12) WATER QUALITY:  
Was a chemical analysis made? Yes  No   
Did any strata contain undesirable water? Yes  No   
Type of water? GOOD depth of strata 3

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E. A. HOLLY (Type or Print) Water Well Drillers Registration No. 8011  
ADDRESS Box 37 (Street or RFD) RIVERSIDE (City) TEXAS 77367 (State)  
(Signed) E. A. Holly (Water Well Driller) E. A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
APR 11 1977  
TEXAS WATER  
DEVELOPMENT BOARD

RECEIVED  
MAY 24 1977  
Central Records  
Texas Water Development Board

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TDWR use only Well No. 60-13-SK Located on map Yes Received: C.F.S.

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Eara Nickens Address Rt. 3, Box 561 Huntsville, Texas 77340
2) LOCATION OF WELL: County Walker 13 miles in NE direction from Huntsville

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines... See attached map.

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging
4) PROPOSED USE (Check): Domestic, Industrial, Public Supply, Irrigation, Test Well, Other
5) DRILLING METHOD (Check): Mud Rotary, Air Hammer, Driven, Bored, Air Rotary, Cable Tool, Jetted, Other

6) WELL LOG: Date drilled 8-10-82
7) BOREHOLE COMPLETION: Open Hole, Straight Wall, Underreamed, Gravel Packed, Other two string const.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From, To, Gage Casing Screen.

CEMENTING DATA
Cemented from 200' ft. to 430' ft.
Method used pressure
Cemented by Clearwater Well Service

9) WATER LEVEL:
Static level 84 ft. below land surface Date 8-12-82
Artesian flow gpm. Date

10) PACKERS: Type Depth
2" K Packer 425'

11) TYPE PUMP:
Turbine, Jet, Submersible, Cylinder, Other
Depth to pump bowls, cylinder, jet, etc., 168' ft.

12) WELL TESTS:
Type Test: Pump, Bailer, Jetted, Estimated
Yield: 40 gpm with 0 ft. drawdown after 2 hrs.

RECEIVED
SEP 13 1982
DEPT. OF WATER RESOURCES

13) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable water? Yes No
If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? Depth of strata
Was a chemical analysis made? Yes No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME Eugene M. Poldrack Water Well Drillers Registration No. 2134
ADDRESS 440 Graham Road Huntsville, Texas 77340
(Signed) Kenneth Young Clearwater Well Service

Please attach electric log, chemical analysis, and other pertinent information, if available.


**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term “Commission” in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

© 1989  
10 TDR  
REPRODUCED FROM



LYNNSTON  
RESERVOIR

Normal Pool  
Elevation 1310

RIVERSIDE  
POP. 225  
ELEV. 1250

COUNTRY  
CAMPUS

HUNTVILLE  
POP. 17,810

HOUSTON NATIONAL  
FOREST

SAM

HUNTVILLE  
STATE PARK

G R I M S C O U N T Y

M O N

M A D

To Dallas  
To Masonville

99°40'

30°50'

99°45'


30°45'

99°50'

30°40'

99°55'

30°35'



Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TDWR use only  
Well No. 60-13-55  
Located on map W82  
Received: 79 84

1) OWNER H.R. SAIRLEY (Name) Address 10901 OSWEGO HOUSTON TEXAS 77029 (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL: County WALKER 6 S miles in RIVERSIDE direction from RIVERSIDE (N.E., S.W., etc.) (Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.

Legal description:  
Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

See attached map. #11, Map on 80-20-46

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 4-8-79  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6 1/2 Surface 402  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.)	Gage Casing Screen	
						From	To	
0	22	SURFACE SAND						
22	42	SANDY CLAY						
42	92	BROWN CLAY	4 N		PLASTIC	388	+1	SC# 40
92	102	BLUE CLAY						
102	120	SAND						
120	138	BLUE CLAY						
138	142	FINE SAND						
142	218	BLUE CLAY						
218	224	FINE SAND						
224	364	MEALY CLAY						
364	402	SAND						

CEMENTING DATA  
Cemented from 388 ft. to 300 ft.  
Method used PRESSURE  
Cemented by E.A. HOLLY (Company or Individual)

9) WATER LEVEL:  
Static level 140 ft. below land surface Date 4-8-79  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type Depth  
#11  
LEAD 25' 384

11) TYPE PUMP:  
 Turbin  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., \_\_\_\_\_ ft.

12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? GOOD Depth of strata 38  
Was a chemical analysis made?  Yes  No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State) (Zip)  
(Signed) E.A. Holly E.A. HOLLY CO (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**2) LOCATION OF WELL:**

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2 of the TDWR-0392 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED

JUL 6 '79

CR/TDWR

RECEIVED

APR 19 1979

DEPT. OF  
WATER RESOURCES

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TDWR use only  
Well No. 60-13-SR  
Located on map W22  
Received: 7-9-84

1) OWNER NORMAN FRAZIER (Name) Address 4302 OAKSIDE HOUSTON TEXAS 77053 (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL: County WALKER 6 miles in S direction from RIVERSIDE (Town) (N.E., S.W., etc.)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.

Legal description:  
Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

X See attached map. #10, Map on 60-20-4G

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 4-7-79  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6 1/2 Surface 317  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.)		Gage Casing Screen
						From	To	
0	24	BROWN CLAY						
24	58	WHITE CLAY						
58	242	BLUE CLAY	4	N	PLASTIC	305	71	SC40
242	244	SAND						
244	305	BLUE CLAY	2 1/2	N	STAINLESS STEEL	307	317	#10
305	317	SAND						

CEMENTING DATA  
Cemented from 305 ft. to 300 ft.  
Method used PRESSURE  
Cemented by E.A. HOLLY CO (Company or Individual)

9) WATER LEVEL:  
Static level 135 ft. below land surface Date 4-7-79  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

#10

10) PACKERS: Type Depth  
LEAD 300

11) TYPE PUMP:  
 Turbin  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 220 ft.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? GOOD Depth of strata 12  
Was a chemical analysis made?  Yes  No

12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 (Street or RFD) RIVERSIDE (City) TEXAS (State) 77367 (Zip)  
(Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**2) LOCATION OF WELL:**

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2 of the TDWR-0392 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED

JUL 6 '79

CR/TDWR

RECEIVED

APR 19 1979

DEPT. OF  
WATER RESOURCES

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

For TDWR use only Well No. 60-13-5R Located on map YES Received: TH

1) OWNER JACK MILLER (Name) Address RT 1 Box 52-A MIDWAY TEXAS 75852 (Street or RFD) (City) (State) (Zip)
2) LOCATION OF WELL: County WALKER 7 miles in S direction from RIVERSIDE (Town)

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map. Map on 60-22-7E

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Public Supply Irrigation Test Well Other
5) DRILLING METHOD (Check): Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG: Date drilled 10-3-79 DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) Surface 240
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval . . . from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include: 0-62 BROWN CLAY, 62-102 SANDY CLAY, 102-122 BROWN CLAY, 122-184 WHITE CLAY, 184-196 ROCK, 196-231 WHITE CLAY, 231-240 SAND, 4 N PLASTIC, 22 N STAINLESS STEEL.

CEMENTING DATA Cemented from 230 ft. to 200 ft. Method used PRESSURE Cemented by E.A. HOLLY (Company or Individual)

9) WATER LEVEL: Static level 80 ft. below land surface Date 10-3-79 Artesian flow gpm. Date

10) PACKERS: Type Depth LEAD 225

11) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 200 ft.

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water? GOOD Depth of strata 9 Was a chemical analysis made? No
12) WELL TESTS: Type Test: Pump Bailer Jetted Estimated Yield: gpm with ft. drawdown after hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Signed) E.A. HOLLY E.A. HOLLY CO. (Company Name)

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term “Commission” in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

DEPT. OF  
WATER RESOURCES  
OCT 24 1979  
RECEIVED

RECEIVED  
MAR 19 '80  
CR/TDWR

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-13-56 Located on map 409 Received: 5/8/78

1) OWNER: Person having well drilled MR BOBBY OBANNION Address RT 6 HUNTSVILLE TEXAS Landowner SAME Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER, 3 miles in S direction from RIVERSIDE (N.E., S.W., etc.) (Town)



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging. 4) PROPOSED USE (Check): Domestic, Industrial, Municipal, Irrigation, Test Well, Other. 5) TYPE OF WELL (Check): Rotary, Driven, Dug, Cable, Jetted, Bored.

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 253 ft. Depth of completed well 253 ft. Date drilled 5-8-78 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-24 SURFACE SOIL & CLAY, 24-44 BLUE CLAY, 44-56 SAND, 56-114 BROWN CLAY, 114-240 BLUE CLAY, 240-253 SAND.

9) CASING: Type: Old, New, Steel, Plastic, Other. Cemented from 243 ft. to 200 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage. 4 243 +1 50#40. 10) SCREEN: Type STAINLESS STEEL. Perforated, Slotted. Diameter (inches) Setting From (ft.) To (ft.) Slot Size. 2 1/2 243 253 #10.

7) COMPLETION (Check): Straight wall, Gravel packed, Other, Under reamed, Open Hole.

11) WELL TESTS: Was a pump test made? Yes No. If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm. Temperature of water.

8) WATER LEVEL: Static level 75 ft. below land surface Date 5-11-78. Artesian pressure lbs. per square inch Date. Depth to pump bowls, cylinder, jet, etc., 120 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No. Did any strata contain undesirable water? Yes No. Type of water? Good depth of strata 13.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS (Signed) E.A. Holly (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED

MAY 16 1978

DEPT. OF  
WATER RESOURCES

RECEIVED  
AUG 30 1978

Central Records  
Texas Dept. of Water Resources

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-13-5P Located on map YPS Received: 78 YPS alt

1) OWNER: Person having well drilled COUNTRY CAMPUS CHURCH Address RT 3 HUNTSVILLE TEXAS Landowner SAME Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER 3 miles in S direction from RIVERSIDE (N.E., S.W., etc.) (Town)



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Irrigation Test Well Municipal Other 5) TYPE OF WELL (Check): Rotary Driven Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 214 ft. Depth of completed well 214 ft. Date drilled 5-25-78 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include SURFACE CLAY, WHITE CLAY, BLUE CLAY, SAND, BLUE CLAY, SAND, BLUE CLAY, SAND.

9) CASING: Type: Old New Steel Plastic Other Cemented from 204 ft. to 150 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 4 204 +1 SCH 40

10) SCREEN: Type STAINLESS STEEL Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size 2 1/2 204 214 # 6

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

8) WATER LEVEL: Static level 85 ft. below land surface Date 5-25-78 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 180 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? GOOD depth of strata 10

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 128 YAN 801 ADDRESS Box 37 RIVERSIDE TEXAS (Signed) E.A. Holly E.A. HOLLY CO.

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED

MAY 30 1978

DEPT. OF  
WATER RESOURCES

AUG 30 1978

Texas Dept. of Water Resources

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-13-5N Located on map 425 Received: 11/25/77 dr

1) OWNER: Person having well drilled LENA MARTIN Address Box 283 HUNTSVILLE TEXAS Landowner SAME

2) LOCATION OF WELL: County WALKER, 4 miles in S direction from RIVERSIDE



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging. 4) PROPOSED USE (Check): Domestic, Industrial, Municipal, Irrigation, Test Well, Other. 5) TYPE OF WELL (Check): Rotary, Driven, Dug, Cable, Jetted, Bored.

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 161 ft. Depth of completed well 161 ft. Date drilled 5-18-77 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows: 0-48 WHITE CLAY, 48-51 SAND, 51-116 WHITE CLAY, 116-151 BROWN CLAY, 151-161 SAND.

9) CASING: Type: Old, New, Steel, Plastic, Other. Cemented from 151 ft. to 100 ft. Diameter (inches) 4, Setting From (ft.) 151, To (ft.) 1, Gage SCH 40.

(Use reverse side if necessary)

10) SCREEN: Type STAINLESS STEEL. Perforated, Slotted. Diameter (inches) 2 1/2, Setting From (ft.) 151, To (ft.) 161, Slot Size #10.

7) COMPLETION (Check): Straight wall, Gravel packed, Other, Under reamed, Open Hole.

11) WELL TESTS: Was a pump test made? Yes No. Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm. Temperature of water.

8) WATER LEVEL: Static level 50 ft. below land surface Date 5-18-77. Depth to pump bowls, cylinder, jet, etc., 120 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No. Did any strata contain undesirable water? Yes No. Type of water? Good depth of strata 10.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Signed) E.A. HOLLY (Water Well Driller) E.A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
GENERAL INVESTIGATIVE  
DIVISION  
JUL 29 1953  
FEDERAL BUREAU OF  
INVESTIGATION  
U. S. DEPARTMENT OF JUSTICE

RECEIVED  
JUL 29 1953

U. S. DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION

Dupl


Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 60-13-5N Located on map 405 Received: 78 105

1) OWNER: Person having well drilled MR EARL HASS Address P.O. Box 1058 HUNTSVILLE, TEXAS Landowner SAME

2) LOCATION OF WELL: County WALKER, 5 miles in S direction from RIVERSIDE



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging. 4) PROPOSED USE (Check): Domestic, Industrial, Municipal, Irrigation, Test Well, Other. 5) TYPE OF WELL (Check): Rotary, Driven, Dug, Cable, Jetted, Bored.

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 232 ft. Depth of completed well 232 ft. Date drilled 11-21-77. All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-26 TOP SOIL & CLAY, 26-45 BLUE CLAY, 45-48 SAND, 48-183 BLUE CLAY, 183-187 SAND, 187-222 BLUE CLAY, 222-232 SAND.

9) Casing: Type: Old, New, Steel, Plastic, Other. Cemented from 122 ft. to 75 ft. Diameter (inches) 4, Setting From (ft.) 122 To (ft.) 71 Gage SCH 40. 10) SCREEN: Type STAINLESS STEEL. Perforated, Slotted. Diameter (inches) 2 1/2, Setting From (ft.) 122 To (ft.) 132 Slot Size # 8.

7) COMPLETION (Check): Straight wall, Gravel packed, Other, Under reamed, Open Hole.

11) WELL TESTS: Was a pump test made? Yes No. If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm. Temperature of water.

8) WATER LEVEL: Static level 50 ft. below land surface Date 11-21-77. Artesian pressure lbs. per square inch. Date. Depth to pump bowls, cylinder, jet, etc., 160 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No. Did any strata contain undesirable water? Yes No. Type of water? Good depth of strata 10 FT.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS P.O. Box 37 RIVERSIDE TEXAS (Signed) E.A. HOLLY E.A. HOLLY CO.

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

SECURITY INFORMATION  
NOV 22 1977

RECEIVED

RECEIVED  
JAN 30 1978

Central Records  
Texas Dept. of Water Resources

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas


WATER WELL REPORT

For TWDB use only  
Well No. 60-13-5L  
Located on map yes  
Received: 27  
alt

1) OWNER:  
Person having well drilled EWING L PURSLEY Address \_\_\_\_\_  
(Name) (Street or RFD) (City) (State)  
Landowner SAME Address SAME  
(Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County WALKER, 10 miles in NE direction from HUNTSVILLE  
(N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, or Give legal location with distances and directions from adjacent sections or survey lines.  
hiway number, etc.\*



Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW¼ NE¼ SW¼ SE¼) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging

4) PROPOSED USE (Check):  
 Domestic  Industrial  Municipal  Irrigation  Test Well  Other

5) TYPE OF WELL (Check):  
 Rotary  Driven  Dug  Cable  Jetted  Bored

6) WELL LOG:  
Diameter of hole 6 3/4 in. Depth drilled 150 ft. Depth of completed well 151 ft. Date drilled 12-17-74  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	25	top SAND
25	30	ROCK
50	100	fullers earth
100	135	BROKEN ROCK
135	140	clay
140	150	SAND
150	151	clay

9) Casing:  
Type: Old  New  Steel  Plastic  Other \_\_\_\_\_  
Cemented from 0 ft. to 0 ft.

Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
4" 0 151 sch 40

10) SCREEN:  
Type plastic sch 40  
Perforated  Slotted

Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Slot Size \_\_\_\_\_  
4" 140 150 012

7) COMPLETION (Check):  
 Straight wall  Gravel packed  Other \_\_\_\_\_  
 Under reamed  Open Hole

11) WELL TESTS:  
Was a pump test made? Yes  No  If yes, by whom? \_\_\_\_\_  
Yield: 18 gpm with 10 ft. drawdown after 1 hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_

8) WATER LEVEL:  
Static level 22 ft. below land surface Date 12-18-76  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date 12-18  
Depth to pump bowls, cylinder, jet, etc., 132 ft. below land surface.

12) WATER QUALITY:  
Was a chemical analysis made? Yes  No   
Did any strata contain undesirable water? Yes  No   
Type of water? soft depth of strata 10'

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME W. A. Waller Water Well Drillers Registration No. 1332  
(Type or Print)  
ADDRESS Box 516 New Waverly TEXAS  
(Street or RFD) (City) (State)  
(Signed) W. A. Waller AAA WATER WELLS  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

CHIEF ENGINEER  
TARRANT COUNTY  
WATER DEPARTMENT  
DALLAS, TEXAS  
APR 10 1953  
FILED

WELL LOCATION SKETCH

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TDWR use only  
Well No. 60-13-5L  
Located on map Wes  
Received: 7/9/81

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER MR ROSS TAYLOR (Name) Address RT 1 Box 291 HUNTSVILLE, TEXAS 77340 (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL: County WALKER 5 miles in S direction from RIVERSIDE (Town)

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.  
 Legal description: Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

See attached map. Map on 60-20-5C

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 6-14-79  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
6 1/2 Surface 152  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial	Setting (ft.) From	Setting (ft.) To	Gage Casing Screen
<u>0</u>	<u>62</u>	<u>BROWN CLAY</u>						
<u>62</u>	<u>72</u>	<u>SAND</u>						
<u>72</u>	<u>76</u>	<u>BROWN CLAY</u>						
<u>76</u>	<u>83</u>	<u>SAND STKS</u>			<u>4 N PLASTIC</u>	<u>147</u>	<u>11</u>	<u>8 1/4</u>
<u>83</u>	<u>122</u>	<u>BROWN CLAY</u>						
<u>122</u>	<u>157</u>	<u>SAND</u>			<u>2 1/2 N STAINLESS STEEL</u>	<u>147</u>	<u>152</u>	<u>#10</u>

CEMENTING DATA  
Cemented from 147 ft. to 100 ft.  
Method used PRESSURE  
Cemented by E.A. HOLLY CO (Company or Individual)

9) WATER LEVEL:  
Static level 32 ft. below land surface Date 6-14-79  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type Depth  
LEAD 137

11) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 120 ft.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? GOOD Depth of strata \_\_\_\_\_  
Was a chemical analysis made?  Yes  No

12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State) (Zip)  
(Signed) [Signature] (Water Well Driller) E.A. HOLLY CO (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).


RECEIVED  
AUG 13 '79  
CR/TDWR

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TWDB use only  
Well No. 60-13-5K  
Located on map YCS  
Received: 76  
dlr

1) OWNER:  
Person having well drilled CHARLIE HAYNES (Name) Address RT 2 Box 685 WILLIS, TEXAS (Street or RFD) (City) (State)  
Landowner SAME (Name) Address \_\_\_\_\_ (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County WALKER, 5 miles in S direction from RIVERSIDE (N.E., S.W., etc.) (Town)  
Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\*  
  
Give legal location with distances and directions from adjacent sections or survey lines.  
Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW $\frac{1}{4}$  NE $\frac{1}{4}$  SW $\frac{1}{4}$  SE $\frac{1}{4}$ ) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Municipal  Irrigation  Test Well  Other  
5) TYPE OF WELL (Check):  
 Rotary  Driven  Dug  Cable  Jetted  Bored

6) WELL LOG:  
Diameter of hole 6 1/2 in. Depth drilled 163 ft. Depth of completed well 163 ft. Date drilled 10-1-76  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	70	WHITE CLAY
70	77	ROCK
77	148	WHITE CLAY
148	163	SAND

9) CASING:  
Type: Old \_\_\_\_\_ New \_\_\_\_\_ Steel \_\_\_\_\_ Plastic \_\_\_\_\_ Other \_\_\_\_\_  
Cemented from 153 ft. to 75 ft.  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
4 153 + 1 SCH 40  
10) SCREEN:  
Type STAINLESS STEEL  
Perforated \_\_\_\_\_ Slotted \_\_\_\_\_  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Slot Size \_\_\_\_\_  
2 1/2 153 163 #6

7) COMPLETION (Check):  
 Straight wall  Gravel packed  Other \_\_\_\_\_  
 Under reamed  Open Hole \_\_\_\_\_  
8) WATER LEVEL:  
Static level 45 ft. <sup>45</sup> below land surface Date 10-1-76  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 120 ft. below land surface.

11) WELL TESTS:  
Was a pump test made? Yes \_\_\_\_\_ No \_\_\_\_\_ If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_  
12) WATER QUALITY:  
Was a chemical analysis made? Yes \_\_\_\_\_ No \_\_\_\_\_  
Did any strata contain undesirable water? Yes \_\_\_\_\_ No \_\_\_\_\_  
Type of water? GOOD depth of strata 15

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.  
NAME F. A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS BOX 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State)  
(Signed) E. C. HOLLY (Water Well Driller) F. A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
OCT 3 1976  
TEXAS WATER  
DEVELOPMENT BOARD

RECEIVED  
FEB 8 1977

Central Records  
Texas Water Development Board

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only  
Well No. 60-13-56  
Located on map  
Received: 75 4 25  
*all*

1) OWNER:  
Person having well drilled Julie Jefferson Address Rt. 3 Huntsville, Texas  
(Name) (Street or RFD) (City) (State)  
Landowner same Address \_\_\_\_\_  
(Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County Walker 9 miles in NE direction from Huntsville  
(N.E., S.W., etc.) (Town)



Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\*  
or Give legal location with distances and directions from adjacent sections or survey lines.

Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW¼ NE¼ SW¼ SE¼) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
New Well Deepening \_\_\_\_\_  
Reconditioning \_\_\_\_\_ Plugging \_\_\_\_\_  
4) PROPOSED USE (Check):  
Domestic Industrial \_\_\_\_\_ Municipal \_\_\_\_\_  
Irrigation \_\_\_\_\_ Test Well \_\_\_\_\_ Other \_\_\_\_\_  
5) TYPE OF WELL (Check):  
Rotary Driven \_\_\_\_\_ Dug \_\_\_\_\_  
Cable \_\_\_\_\_ Jetted \_\_\_\_\_ Bored \_\_\_\_\_

6) WELL LOG:  
Diameter of hole 6½ in. Depth drilled 184 ft. Depth of completed well 184 ft. Date drilled 11-22-74  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	1	surface soil
1	6	white clay
6	28	brown clay
28	140	hard white clay
140	178	blue <del>gray</del> clay
178	184	good sand

9) CASING:  
Type: Old \_\_\_\_\_ New \_\_\_\_\_ Steel \_\_\_\_\_ Plastic \_\_\_\_\_ Other \_\_\_\_\_  
Cemented from 100 ft. to 174 ft.  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
4 +1 174 sch 40  
10) SCREEN: stainless steel  
Type \_\_\_\_\_  
Perforated \_\_\_\_\_ Slotted \_\_\_\_\_  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Slot Size \_\_\_\_\_  
2½ 174 184 #10

(Use reverse side if necessary)  
7) COMPLETION (Check):  
Straight wall Gravel packed \_\_\_\_\_ Other \_\_\_\_\_  
Under reamed \_\_\_\_\_ Open Hole \_\_\_\_\_  
8) WATER LEVEL:  
Static level 52 ft. below land surface Date 11021-74  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 140 ft. below land surface.

11) WELL TESTS:  
Was a pump test made? Yes  No  If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm.  
Temperature of water \_\_\_\_\_  
12) WATER QUALITY:  
Was a chemical analysis made? Yes  No   
Did any strata contain undesirable water? Yes  No   
Type of water? good depth of strata \_\_\_\_\_

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.  
NAME E.A. Holly Water Well Drillers Registration No. 801  
(Type or Print)  
ADDRESS P.O. Box 37 Riverside Texas 77367  
(Street or RFD) (City) (State)  
(Signed) E.A. Holly E.A. Holly Co  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

File to [unclear]  
[unclear]  
[unclear]  
[unclear]  
[unclear]  
[unclear]

RECEIVED  
NOV 25 1974  
TEXAS WATER  
DEVELOPMENT BOARD

RECEIVED  
JUN 12 1975  
General Records  
Texas Water Development Board

#2 WALKER

Dup

1) OWNER Walter Bennett Address P.O. Box 165 Orchard, Texas 77464  
(Name) (Street or RFD) (City) (State) (Zip)

2) LOCATION OF WELL:  
County Walker 4 miles in SW direction from Riverside  
(N.E., S.W., etc.) (Town)

Legal description:  
Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

See attached map. map on 60-21-3B

3) TYPE OF WORK (Check):  
 New Well  Deepening  
 Reconditioning  Plugging

4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  
 Irrigation  Test Well  Other \_\_\_\_\_

5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  
 Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG:  
Date drilled 7-16-80

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
<u>6 1/2</u>	Surface	<u>204</u>

7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	8) CASING, BLANK PIPE, AND WELL SCREEN DATA:
			Dia. (in.)   New or Used   Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial   Setting (ft.) From   To   Gage Casing Screen
0-6		white clay	
6-11		sand streaks	
11-16		sand	#4 N Plastic -1 1/2 192 40
16-18		rock streaks	
18-22		sand	2 1/2 N Stainless steel 193 203 #10
22-35		blue clay	
35-39		sand	
39-55		meally clay	
55-75		sticky white clay	
75-87		blue clay	
87-91		sand	
91-95		rock	
95-112		blue clay	
112-118		sand	
118-138		sand streaks	
138-156		sand	
156-165		sand streaks	
165-194		blue clay	
194-204		sand	

CEMENTING DATA  
Cemented from 192 ft. to 142 ft.  
Method used Pressure  
Cemented by Holly Water Well Service  
(Company or Individual)

9) WATER LEVEL:  
Static level 38 ft. below land surface Date 7-17-80  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type Depth  
Rubber R&R 188

RECEIVED  
APR 7 1982  
CR/TDWR

11) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 160 ft.

12) WELL TESTS:  
 Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata 10 ft.  
Was a chemical analysis made?  Yes  No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME RALPH A. CADWALLADER Water Well Drillers Registration No. 2026  
(Type or Print)

ADDRESS P.O. Box 638 Riverside Texas 77367  
(Street or RFD) (City) (State) (Zip)

(Signed) Ralph A. Cadwallader Holly Water Well Service  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

**RECEIVED**

**SEP 11 1980**

**DEPT. OF  
WATER RESOURCES**

#2 WALKER

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER David Redden Address Rt. # Box 584 Huntsville, TX 77340
2) LOCATION OF WELL: County Walker 5 miles in South direction from Riverside

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map. map on 60-12-1F

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Public Supply Irrigation Test Well Other
5) DRILLING METHOD (Check): Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG: Date drilled 1/6/84 DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 241
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval . . . from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include Top soil, Gumbo, Sand streaks, Rock streaks & Blue clay, Blue clay, Sand, etc.

CEMENTING DATA Cemented from 220 ft. to 120 ft. Method used Pressure Cemented by Henry Lee (Company or Individual)

9) WATER LEVEL: Static level ft. below land surface Date Artesian flow gpm. Date

10) PACKERS: Type Depth Lead L 215

RECEIVED APR 11 1984

DEPT. OF WATER RESOURCES (Use reverse side if necessary)

11) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 160 ft.
12) WELL TESTS: Type Test Pump Bailer Jetted Estimated Yield: gpm with ft. drawdown after hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221
ADDRESS Rt. 11 Box 607 Huntsville, TX 77340
(Signed) [Signature] (Signed) [Signature]

Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 60-13-5G Located on map YES C.F.S.

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

STATE OF TEXAS  
DEPARTMENT OF WATER RESOURCES  
AUSTIN, TEXAS

Dep

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-13-5F Located on map yes Received: 77 alt

1) OWNER: Person having well drilled MR GLEN BOATRIGHT Address Rt 4 Box 228 HUNTSVILLE, TEXAS Landowner SAME Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER 4 miles in 5 direction from RIVERSIDE Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\* RIVERSIDE FM 980 HUNTSVILLE

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Irrigation Test Well Municipal Other 5) TYPE OF WELL (Check): Rotary Driven Cable Jetted Bored Dug Bored

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 185 ft. Depth of completed well 185 ft. Date drilled 5-31-77 All measurements made from ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows: 0-23 WHITE CLAY, 23-26 SAND, 26-49 WHITE, 49-175 BLUE CLAY, 175-185 SAND

9) CASING: Type: Old New Steel Plastic Other Cemented from 175 ft. to 100 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 4 175 +1 SCH 40 10) SCREEN: Type STAINLESS STEEL Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size 2 1/2 175 185 # 12

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole 8) WATER LEVEL: Static level 7 ft. below land surface Date 5-31-77 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 140 ft. below land surface.

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water 12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? Good depth of strata 10

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS (Signed) E.A. HOLLY F.A. HOLLY CO 77367

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
JUN 3 1977  
TEXAS WATER  
DEVELOPMENT BOARD

JUL 28 1977  
Texas Water Development Board


Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TWDB use only  
Well No. 62-13-5E  
Located on map Yes  
Received: 72  
dl

1) OWNER:  
Person having well drilled Mr Jim White Address Gen Del. Riverside, Texas  
(Name) (Street or RFD) (City) (State)  
Landowner Same Address \_\_\_\_\_  
(Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County Walker miles in 3 1/2 S direction from Riverside, Texas  
(N.E., S.W., etc.) (Town)



Give legal location with distances and directions from adjacent sections or survey lines.  
Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
New Well Deepening  
Reconditioning Plugging  
4) PROPOSED USE (Check):  
Domestic Industrial Municipal  
Irrigation Test Well Other  
5) TYPE OF WELL (Check):  
Rotary Driven Dug  
Cable Jetted Bored

6) WELL LOG:  
Diameter of hole 6 1/2 in. Depth drilled 487 ft. Depth of completed well 487 ft. Date drilled 12-23-71  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	71	Brown Clay
71	163	Blue Clay
163	209	sandy blue clay
209	224	Hard Rock
224	301	Blue Clay & Rock stks.
301	389	blue clay
389	399	fine sand
399	477	Sticky Blue Clay
477	487	Sand (Med Fine)

9) Casing:  
Type: Old New Steel Plastic Other  
Cemented from 476 ft. to 425 ft.  
Diameter (inches) 4 Setting From (ft.) X-1 To (ft.) 476 Gage Scn. 40

10) SCREEN:  
Type Stainless Steel Bar-Weld  
Perforated \_\_\_\_\_ Slotted \_\_\_\_\_  
Diameter (inches) 2 1/2 Setting From (ft.) 476 To (ft.) 487 Slot Size #6

7) COMPLETION (Check):  
Straight wall Gravel packed Other  
Under reamed Open Hole

11) WELL TESTS:  
Was a pump test made? Yes No If yes, by whom?  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_

8) WATER LEVEL:  
Static level 110 ft. below land surface Date 12-23-71  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 210 ft. below land surface.

12) WATER QUALITY:  
Was a chemical analysis made? Yes No  
Did any strata contain undesirable water? Yes No  
Type of water? good depth of strata 10

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. Holly Water Well Drillers Registration No. 801  
(Type or Print)  
ADDRESS Box 37 Riverside Texas 77367  
(Street or RFD) (City) (State)  
(Signed) E.A. Holly E.A. Holly Company  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

[Faint, mostly illegible text and markings, possibly a map or survey data, scattered across the middle of the page.]

RECEIVED  
MAR 27 1972

Central Records  
Texas Water Development Board

TEXAS WATER DEVELOPMENT BOARD

JAN 4 1972

RECEIVED

RECEIVED

SEP 22 1978

Dwp

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas


WATER WELL REPORT

DEPT. OF WATER RESOURCES

For TWDB use only Well No. 60-13-5E Located on map Yes Received: 79

1) OWNER: Person having well drilled Tucker Ozier Address Huntsville Tex Landowner Same Address Same

2) LOCATION OF WELL: County Walker, 10 miles in NE direction from Huntsville



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Municipal Irrigation Test Well Other 5) TYPE OF WELL (Check): Rotary Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 3/4 in. Depth drilled 271 ft. Depth of completed well 271 ft. Date drilled 9-11-78 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include top soil, rock (sandstone), sand, and rock layers.

9) CASING: Type: Old New Steel Plastic Other Cemented from 0 ft. to 0 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 4" 0 241 sch 40 10) SCREEN: Type plastic sch 40 Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size 4" 241 271 012

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: 50 gpm with 10 ft. drawdown after 1 hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

8) WATER LEVEL: Static level 85 ft. below land surface Date 9-15-78 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 160 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? soft depth of strata 21

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME James L. Graham SR Water Well Drillers Registration No. 1781 ADDRESS Rt 3 Box 150 Willis Tex 77378 (Signed) James L. Graham (Water Well Driller) AAA Water Wells (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
MAR 16 '79  
CR/TDWR

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 60-13-5D Located on map yes Received: 7/1/71 Form GW 8 Form GW 9

1) OWNER: Mr R.E. Morris Rt 5 Box 112 Same Landowner

2) LOCATION OF WELL: Walker County Riverside, Texas FM 1980 Highway #19 Well

3) TYPE OF WORK (Check): New Well [x] Deepening [ ] Reconditioning [ ] Plugging [ ] 4) PROPOSED USE (Check): Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] 5) TYPE OF WELL (Check): Rotary [x] Driven [ ] Dug [ ] Cable [ ] Jetted [ ] Bored [ ]

6) WELL LOG: Diameter of hole 6 in. Depth drilled 83 ft. Depth of completed well 83 ft. Date drilled 3-5-71 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows: 0-26 Surface Soils, 26-35 white clay, 35-65 Sticky white clay, 65-83 sand

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Includes note: (Use reverse side if necessary)

7) COMPLETION (Check): Straight wall [x] Gravel packed [ ] Other [ ] Under reamed [ ] Open hole [ ]

8) WATER LEVEL: Static level 35 ft. below land surface Date 3-5-71 Artesian pressure lbs. per square inch Date

9) CASING: Type: old [ ] New [x] Steel [x] Plastic [ ] Other [ ] Cemented from 65 ft. to 20 ft.

10) SCREEN: Type Stainless Steel Bar-Weld Perforated [ ] Slotted [ ]

Table with 4 columns: Diameter (inches), Setting From (ft.), Setting To (ft.), Gage. Row: 4, x-1, 72, Sch. 40

Table with 4 columns: Diameter (inches), Setting From (ft.), Setting To (ft.), Slot size. Row: 2, 73, 83, 8

11) WELL TESTS: Was a pump test made? [ ] Yes [x] No If yes by whom? Yield: gpm with ft. drawdown after hrs Bailer test gpm with ft. drawdown after hrs Artesian flow gpm Date Temperature of water Was a chemical analysis made? [ ] Yes [x] No Did any strata contain undesirable water? [ ] Yes [x] No Type of water? good depth of strata 18

12) PUMP DATA: Manufacturer's Name Ruth Berry Type Electric Submer. H.P. 1/2 Designed pumping rate 800 gpm gph [x] Type power unit Electric Depth to bowls, cylinder, jet, etc., 70 ft. below land surface.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. Holly Water Well Drillers Registration No. 801 Address Box 37 Riverside Texas (Signed) E.A. Holly Company (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Faint header text at the top of the page.

Faint text on the right side of the page.

Faint text in the middle of the page.

Faint text on the right side, possibly a date or reference number.

Faint text in the lower middle section.

**RECEIVED**  
JUN 18 1971

Central Records  
Texas Water Development Board

RECEIVED  
MAY 21 1971  
TEXAS WATER  
DEVELOPMENT BOARD

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

For TWDB use only  
Well No. 60-13-5c  
Located on map 3008  
Received: 9-15-70  
Form GW 8 \_\_\_\_\_  
Form GW 9 \_\_\_\_\_

1) OWNER:  
Person having well drilled Mr Clyde Richerson Address Route 3 Huntsville, Texas  
(Name) (Street or RFD) (City) (State)  
Landowner Same Address \_\_\_\_\_  
(Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County Walker Labor \_\_\_\_\_ League \_\_\_\_\_ Abstract No. \_\_\_\_\_  
NW 1/4 NE 1/4 SW 1/4 SE 1/4 of Section \_\_\_\_\_ Block No. \_\_\_\_\_ Survey \_\_\_\_\_  
(Circle as many as are known)  
miles in 5 miles S direction from Riverside, Texas.  
(NE, SW, etc.) (Town)  
Sketch map of well location with distances from adjacent section or survey lines, and to landmarks, roads, and creeks.  
*RIVERSIDE, TEXAS*  
*HIGHWAY #19*  
*HUNTSVILLE, TEXAS*  
NORTH ↑

3) TYPE OF WORK (Check):  
New Well  Deepening   
Reconditioning  Plugging

4) PROPOSED USE (Check):  
Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

5) TYPE OF WELL (Check):  
Rotary  Driven  Dug   
Cable  Jetted  Bored

6) WELL LOG:  
Diameter of hole 6 in. Depth drilled 307 ft. Depth of completed well 307 ft. Date drilled 9-15-70  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	10	Clay
10	26	Sand
26	47	clay and sandy strks
47	126	blue clay
126	214	Soft blue clay
214	220	hard clay
220	294	Blue clay

From (ft.)	To (ft.)	Description and color of formation material
294	307	Good sand

(Use reverse side if necessary)

7) COMPLETION (Check):  
Straight wall  Gravel packed  Other   
Under reamed  Open hole

8) WATER LEVEL:  
Static level 75 ft. below land surface Date 9-14-70  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

9) CASING:  
Type: old  New  Steel  Plastic  Other   
Cemented from 286 ft. to 186 ft.

10) SCREEN:  
Type Bar-Weld Stainless Steel  
Perforated  Slotted

Diameter (inches)	Setting		Gage
	From (ft.)	To (ft.)	
4	X-1	286	Sch. 40

Diameter (inches)	Setting		Slot size
	From (ft.)	To (ft.)	
2 1/2	286	307	10

11) WELL TESTS:  
Was a pump test made?  Yes  No If yes by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs  
Artesian flow \_\_\_\_\_ gpm Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_  
Was a chemical analysis made?  Yes  No  
Did any strata contain undesirable water?  Yes  No  
Type of water? good depth of strata 23ft.

12) PUMP DATA:  
Manufacturer's Name Ruth-Berry  
Type Submersible H.P. 3/4  
Designed pumping rate 840 gpm  gph   
Type power unit Electric  
Depth to bowls, cylinder, jet, etc., 147 ft. below land surface.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. Holly (Type or Print) Water Well Drillers Registration No. 801  
Address P.O. Box 37 Riverside Texas 77367  
(Street or RFD) (City) (State)  
(Signed) E.A. Holly E.A. Holly Company  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

8

out of the...

...

...

...

-1-1-5

...

...

-1-1-5

...

...

...

...

...

...

...

RECEIVED  
SEP 17 1970  
TEXAS WATER  
DEVELOPMENT BOARD

...

...

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only  
Well No. 60-13-5F  
Located on map YPS  
Received: 7/3/73  
*dlr*

1) OWNER:  
Person having well drilled L. D. PATTEN (Name) Address P.O. Box 488 HUNTSVILLE TEXAS (Street or RFD) (City) (State)  
Landowner SAME (Name) Address \_\_\_\_\_ (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County WALKER miles in 5 direction from RIVERSIDE (N.E., S.W., etc.) (Town)



or Give legal location with distances and directions from adjacent sections or survey lines.  
Labor \_\_\_\_\_ League \_\_\_\_\_  
Block \_\_\_\_\_ Survey \_\_\_\_\_  
Abstract No. \_\_\_\_\_  
(NW $\frac{1}{4}$  NE $\frac{1}{4}$  SW $\frac{1}{4}$  SE $\frac{1}{4}$ ) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
New Well  Deepening \_\_\_\_\_  
Reconditioning \_\_\_\_\_ Plugging \_\_\_\_\_

4) PROPOSED USE (Check):  
Domestic  Industrial \_\_\_\_\_ Municipal \_\_\_\_\_  
Irrigation \_\_\_\_\_ Test Well \_\_\_\_\_ Other \_\_\_\_\_

5) TYPE OF WELL (Check):  
Rotary  Driven \_\_\_\_\_ Dug \_\_\_\_\_  
Cable \_\_\_\_\_ Jetted \_\_\_\_\_ Bored \_\_\_\_\_

6) WELL LOG:  
Diameter of hole 6 1/2 in. Depth drilled 225 ft. Depth of completed well 225 ft. Date drilled 8-19-73  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	31	HARD WHITE CLAY
31	46	BROWN CLAY
46	211	WHITE CLAY
211	225	SAND

9) CASING:  
Type: Old \_\_\_\_\_ New  Steel \_\_\_\_\_ Plastic \_\_\_\_\_ Other \_\_\_\_\_  
Cemented from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Gage \_\_\_\_\_  
4 213 +1 SC# 40

7) COMPLETION (Check):  
Straight wall  Gravel packed \_\_\_\_\_ Other \_\_\_\_\_  
Under reamed \_\_\_\_\_ Open Hole \_\_\_\_\_

10) SCREEN:  
Type STAINLESS STEEL  
Perforated \_\_\_\_\_ Slotted \_\_\_\_\_  
Diameter (inches) \_\_\_\_\_ Setting From (ft.) \_\_\_\_\_ To (ft.) \_\_\_\_\_ Slot Size \_\_\_\_\_  
2 1/2 213 225 #6

8) WATER LEVEL:  
Static level 63 ft. below land surface Date 9-1-73  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., \_\_\_\_\_ ft. below land surface.

11) WELL TESTS:  
Was a pump test made? Yes \_\_\_\_\_ No  If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_

12) WATER QUALITY:  
Was a chemical analysis made? Yes \_\_\_\_\_ No   
Did any strata contain undesirable water? Yes \_\_\_\_\_ No   
Type of water? GOOD depth of strata 14

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E. A. HOLLY (Type or Print) Water Well Drillers Registration No. 801  
ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Street or RFD) (City) (State)  
(Signed) E. A. HOLLY (Water Well Driller) E. A. HOLLY CO. (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

TEXAS WATER  
DEVELOPMENT BOARD

SEP 20 1973

RECEIVED

RECEIVED  
JAN 8 1973  
Central Records  
Texas Water Development Board

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas


WATER WELL REPORT

For TWDB use only  
Well No. 60-13-5J  
Located on map  
Received: 76 4 5  
dlr

1) OWNER:  
Person having well drilled John London (Name) Address Huntsville Tex (Street or RFD) (City) (State)  
Landowner John London (Name) Address Huntsville Tex (Street or RFD) (City) (State)

2) LOCATION OF WELL:  
County Walker, 9 miles in NE direction from Huntsville Tex (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\*



or Give legal location with distances and directions from adjacent sections or survey lines.

Labor \_\_\_\_\_ League \_\_\_\_\_

Block \_\_\_\_\_ Survey \_\_\_\_\_

Abstract No. \_\_\_\_\_

(NW¼ NE¼ SW¼ SE¼) of Section \_\_\_\_\_

3) TYPE OF WORK (Check):  
New Well  Deepening \_\_\_\_\_  
Reconditioning \_\_\_\_\_ Plugging \_\_\_\_\_  
4) PROPOSED USE (Check):  
Domestic  Industrial \_\_\_\_\_ Municipal \_\_\_\_\_  
Irrigation \_\_\_\_\_ Test Well \_\_\_\_\_ Other \_\_\_\_\_  
5) TYPE OF WELL (Check):  
Rotary  Driven \_\_\_\_\_ Dug \_\_\_\_\_  
Cable \_\_\_\_\_ Jetted \_\_\_\_\_ Bored \_\_\_\_\_

6) WELL LOG:  
Diameter of hole 6 3/4 in. Depth drilled 121 ft. Depth of completed well 121 ft. Date drilled 11-20-75  
All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	1	top soil
1	28	clay
28	30	Rock
30	100	shale
100	110	shale & sand
110	121	SAND

9) Casing:  
Type: Old \_\_\_\_\_ New  Steel \_\_\_\_\_ Plastic  Other \_\_\_\_\_  
Cemented from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Diameter (inches)	Setting From (ft.)	To (ft.)	Gage
4"	0	121	0129A

10) SCREEN:  
Type 4" plastic sch 40 0129A  
Perforated  Slotted \_\_\_\_\_

Diameter (inches)	Setting From (ft.)	To (ft.)	Slot Size
4"	110	120	sch 40 0129A

7) COMPLETION (Check):  
Straight wall  Gravel packed \_\_\_\_\_ Other \_\_\_\_\_  
Under reamed \_\_\_\_\_ Open Hole \_\_\_\_\_

8) WATER LEVEL:  
Static level 18 ft. below land surface Date 11-22-75  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 80 ft. below land surface.

11) WELL TESTS:  
Was a pump test made? Yes  If yes, by whom? \_\_\_\_\_  
Yield: 12 gpm with 16 ft. drawdown after 2 hrs.  
Bailer test \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ gpm  
Temperature of water \_\_\_\_\_

12) WATER QUALITY:  
Was a chemical analysis made? Yes   
Did any strata contain undesirable water? Yes \_\_\_\_\_ No \_\_\_\_\_  
Type of water? soft depth of strata 11'

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME AAA Water Wells Water Well Drillers Registration No. 1332  
(Type or Print)  
ADDRESS Box 576 New Waukey Tex  
(Street or RFD) (City) (State)  
(Signed) W.A. Waller AAA Water Wells  
(Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-CW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED  
JUN 8 1976  
Central Records  
Texas Water Development Board

RECEIVED  
JAN - 6 1976  
TEXAS WATER  
DEVELOPMENT BOARD

RECEIVED

SEP 26 1978

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT DEPT. OF WATER RESOURCES

For TDWR use only Well No. 60-13-5B Located on map Yes Received: 79 JAC

1) OWNER Jim Lowe Address Route 6 Box 294A Huntsville Tex 77340

2) LOCATION OF WELL: County WALKER 4 miles in N direction from RIVERSIDE

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines...

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines

X See attached map. #1

3) TYPE OF WORK (Check): X New Well Reconditioning Deepening Plugging

4) PROPOSED USE (Check): X Domestic Irrigation Industrial Test Well Public Supply Other

5) DRILLING METHOD (Check): X Mud Rotary Air Rotary Air Hammer Cable Tool Driven Jetted Bored Other

6) WELL LOG: Date drilled 9-5-78

Table with columns: Dia. (in.), From (ft.), To (ft.), Surface. Values: 6.5, 206

7) BOREHOLE COMPLETION: X Straight Wall Underreamed Gravel Packed Other

Table with columns: From (ft.), To (ft.), Description and color of formation material. Rows: 0-24 CLAY BLACK, 24-29 SAND, 29-81 BLUE CLAY, 81-85 SAND, 85-196 BLUE CLAY, 196-206 SAND

Table with columns: Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.), Gage Casing Screen. Rows: 4 N PLASTIC, 2 1/2 N STAINLESS STEEL

#1

CEMENTING DATA Cemented from 194 ft. to 125 ft. Method used PRESSURE Cemented by F.A. HOLLY

9) WATER LEVEL: Static level 42 ft. below land surface Date 9-5-78

10) PACKERS: Type LEAD Depth 194

11) TYPE PUMP: X Submersible Depth to pump bowls, cylinder, jet, etc., 140 ft.

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? No Type of water? Good Depth of strata 10 FT

12) WELL TESTS: X Jetted Yield: gpm with ft. drawdown after hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Signed) E.A. Holly F.A. HOLLY CO.

Please attach electric log, chemical analysis, and other pertinent information, if available.


2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2 of the TDWR-0392 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.



RECEIVED  
MAR 16 '79  
CR/TDWR


Send original copy by certified mail to the, Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 80-13-5A Located on map Received: Form GW 8 Form GW 9

1) OWNER: Person having well drilled Lassie White Address Gen Del Riverside, Texas Landowner Same

2) LOCATION OF WELL: County Walker Labor League Abstract No. NW 1/4 NE 1/4 SW 1/4 SE 1/4 of Section Block No. Survey miles in 3 S direction from Riverside, Texas



3) TYPE OF WORK (Check): New Well [x] Deepening [ ] Reconditioning [ ] Plugging [ ] 4) PROPOSED USE (Check): Domestic [x] Industrial [ ] Municipal [ ] Irrigation [ ] Test Well [ ] Other [ ] 5) TYPE OF WELL (Check): Rotary [x] Driven [ ] Dug [ ] Cable [ ] Jetted [ ] Bored [ ]

6) WELL LOG: Diameter of hole 6 in. Depth drilled 575 ft. Depth of completed well 575 ft. Date drilled 5-18-70 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include Clay, Rock & Hard blue shale, Blue Shale, Hard sandy Rock, Sand, Hard Rock, Blue shale, Sand.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include Sticky Blue Clay & Sand Strs, Sand.

7) COMPLETION (Check): Straight wall [x] Gravel packed [ ] Other [ ] Under reamed [ ] Open hole [ ]

8) WATER LEVEL: Static level 175 ft. below land surface Date 5-18-70 Artesian pressure lbs. per square inch Date

9) CASING: Type: old [ ] New [x] Steel [ ] Plastic [x] Other [ ] Cemented from 555 ft. to 400 ft.

10) SCREEN: Type Bar-Weld Stainless Steel Perforated [ ] Slotted [ ]

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Gage. Row: 4, X-1, 555, Sc. 40

Table with 4 columns: Diameter (inches), Setting (From (ft.), To (ft.)), Slot size. Row: 2 1/2, 555, 575, 8

11) WELL TESTS: Was a pump test made? [ ] Yes [x] No If yes by whom? Yield: gpm with ft. drawdown after hrs Bailer test gpm with ft. drawdown after hrs Artesian flow gpm Date Temperature of water Was a chemical analysis made? [ ] Yes [x] No Did any strata contain undesirable water? [ ] Yes [x] No Type of water? good depth of strata

12) PUMP DATA: Manufacturer's Name Ruth-Berry Type Submersible H.P. 1 21K Designed pumping rate 700 gpm gph [x] Type power unit Electric Depth to bowls, cylinder, jet, etc., 210 ft. below land surface.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. NAME E.A. Holly Water Well Drillers Registration No. 801 Address P.O. Box 37 Riverside, Texas Texas (Signed) E.A. Holly Company

Please attach electric log, chemical analysis, and other pertinent information, if available.



ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse Side

State of Texas  
WELL REPORT

Texas Water Well Drillers Advisory Council  
P.O. Box 13087  
Austin, TX 78711-3087  
512-239-0530

1) OWNER Dennis Porrovecchio ADDRESS 2892 SH 19 Huntsville Tx 77340  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County Walker 2892 SH 19 Huntsville TX 77340 GRID # 60-13-5  
(Street, RFD or other) (City) (State) (Zip) Long. Lat.

3) TYPE OF WORK (Check):  New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  Monitor  Environmental Soil Boding  Domestic  Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG: Date Drilling: Started 5/28 1999 6/3 1999  
7) DRILLING METHOD (Check):  Driven  Air Rotary  Mud Rotary  Bored  Air Hammer  Cable Tool  Jetted  Other  
DIAMETER OF HOLE: Dia. (in.) From (ft.) To (ft.)  
10 Surface 94

From (ft.)	To (ft.)	Description and color of formation material
0	1	Bit t.s.
1	5	t.s.
5	33	Soft clieche
33	41	Wh. Cl.
41	61	w. & br.cl.
61	71	Sd.st.
71	94	Sd.

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other  
If Gravel Packed give interval ... from 70 ft. to 94 ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC Casino	-1.5	74	
4	N	Slotted Screen	74	94	#35

9) CEMENTING DATA [Rule 338.44(1)]  
Cemented from -1.5 ft. to 10 ft. No. of sacks used 2  
ft. to \_\_\_\_\_ ft. No. of sacks used \_\_\_\_\_  
Method used By pressure  
Cemented by R. McPike  
Distance to septic system field lines or other concentrated contamination \_\_\_\_\_ ft.  
Method of verification of above distance \_\_\_\_\_

13) TYPE PUMP:  Turbine  Jet  Submersible  Cylinder  Other  
Depth to pump bowls, cylinder, jet, etc., 77 ft.

14) WELL TESTS: Type Test:  Pump  Bailor  Jetted  Estimated  
Yield: 25 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata 23  
Was a chemical analysis made?  Yes  No

10) SURFACE COMPLETION:  Specified Surface Slab Installed [Rule 338.44(2)(A)]  
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]  
 Pitless Adapter Used [Rule 338.44(3)(b)]  
 Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL: Static Level 30 ft. below land surface Date \_\_\_\_\_  
Artesian flow \_\_\_\_\_ gpm Date \_\_\_\_\_

12) PACKERS: Type \_\_\_\_\_ Depth \_\_\_\_\_

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Wells WELL DRILLER'S LICENSE NO. 3114W  
(Type or print) (State) (Date)  
ADDRESS 2928 SH 19 Huntsville TX 77340  
(Street or RFD) (City) (State) (Zip)  
(Signed) Raymond McPike (Signed) \_\_\_\_\_  
(Licensed Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse Side

State of Texas  
WELL REPORT

Texas Water Well Drillers Advisory Council  
P.O. Box 13087  
Austin, TX 78711-3087  
512-239-0530

1) OWNER Dennis Porrovecchio ADDRESS 2892 SH 19 Huntsville Tx 77340  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County Walker 2892 SH 19 Huntsville TX 77340 GRID # 60-13-5  
(Street, RFD or other) (City) (State) (Zip) Long. Lat.

3) TYPE OF WORK (Check):  
 New Well  Deepening  
 Reconditioning  Plugging

4) PROPOSED USE (Check):  Monitor  Environmental Soil Boding  Domestic  
 Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG:  
Date Drilling:  
Started 5/28 19 99  
6/3 19 99

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
8	Surface	88

7) DRILLING METHOD (Check):  Driven  
 Air Rotary  Mud Rotary  Bored  
 Air Hammer  Cable Tool  Jetted  
 Other

From (ft.)	To (ft.)	Description and color of formation material
0	1	Bit t.s.
1	6	Wh.cl.
6	33	Soft clieche
33	41	Wh. Cl.
41	61	w. & br.cl.
61	71	Sd.st.
71	88	Sd.

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other  
If Gravel Packed give interval ... from 64 ft. to 88 ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC Casina	-1.5	68	
4	N	Slotted Screen	68	88	#20

(Use reverse side if necessary)

13) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other

Depth to pump bowls, cylinder, jet, etc., 77 ft.

14) WELL TESTS:  
Type Test:  Pump  Bailor  Jetted  Estimated  
Yield: 15 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

9) CEMENTING DATA [Rule 338.44(1)]  
Cemented from -1.5 ft. to 10 ft. No. of sacks used 2  
ft. to \_\_\_\_\_ ft. No. of sacks used \_\_\_\_\_  
Method used By pressure  
Cemented by R. McPike  
Distance to septic system field lines or other concentrated contamination \_\_\_\_\_ ft.  
Method of verification of above distance \_\_\_\_\_

15) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Good Depth of strata 17  
Was a chemical analysis made?  Yes  No

10) SURFACE COMPLETION  
 Specified Surface Slab Installed [Rule 338.44(2)(A)]  
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]  
 Pitless Adapter Used [Rule 338.44(3)(b)]  
 Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL  
Static Level 30 ft. below land surface Date \_\_\_\_\_  
Artesian flow \_\_\_\_\_ gpm Date \_\_\_\_\_

12) PACKERS:  
Type Depth  
1 - 2.5" K-Packer RxR 67'

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Wells  
(Type or print)

WELL DRILLER'S LICENSE NO. JUL 19 1999 3114W

ADDRESS 2928 SH 19  
(Street or RFD)

Huntsville TX 77340  
(City) (State) (Zip)

(Signed) Raymond McPike  
(Licensed Well Driller)

(Signed) \_\_\_\_\_  
(Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Dupl

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

For TWDB use only Well No. 60-13-5A Located on map 78105 Received: 7/8/78

1) OWNER: Person having well drilled MR PHIL HATHORN Address 20030-35 SAM HOUSTON HUNTSVILLE TEXAS Landowner SAME Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER, 3 1/2 miles in S direction from RIVERSIDE (Town) Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.\* RIVERSIDE FM 980 HY COUNTRY CAMPS North 19 WELL (Use reverse side if necessary) Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Municipal Irrigation Test Well Other 5) TYPE OF WELL (Check): Rotary Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 174 ft. Depth of completed well 174 ft. Date drilled 5-17-78 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-10 BROWN SANDY CLAY, 10-12 BROWN SAND, 12-24 BROWN CLAY, 24-46 BROWN SAND, 46-114 BROWN CLAY, 114-162 BLUE CLAY, 162-174 SAND.

9) Casing: Type: Old New Steel Plastic Other Cemented from 164 ft. to 100 ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 4 164 + 1 SCH 40

10) SCREEN: Type STAINLESS STEEL Perforated Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size 2 1/2 164 174 #12

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

8) WATER LEVEL: Static level 58 ft. below land surface Date 5-17-78 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 140 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? Good depth of strata 12

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. Holly Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Signed) E.A. Holly EA. Holly Co. (Water Well Driller) (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

\*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED

MAY 22 1978

DEPT. OF  
WATER RESOURCES

AUG 30 1978

Texas Dept. of Water Resources

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas  
WATER WELL REPORT

Texas Water Well Drillers Board  
P. O. Box 13087  
Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER DAN DAUSEY (Name) Address 344 Highland Ck (Street or RFD) Huntsville (City) TX (State) 77378 (Zip)  
2) LOCATION OF WELL County Walker Co. 9 miles in NE direction from Huntsville (Town)

Legal description:  
Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.  
Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_  
Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_  
 See attached map.

3) TYPE OF WORK (Check):  
 New Well  Deepening  Reconditioning  Plugging  
4) PROPOSED USE (Check):  
 Domestic  Industrial  Public Supply  Irrigation  Test Well  Other \_\_\_\_\_  
5) DRILLING METHOD (Check):  
 Mud Rotary  Air Hammer  Driven  Bored  Air Rotary  Cable Tool  Jetted  Other \_\_\_\_\_

6) WELL LOG: Date drilled 4/14/87  
DIAMETER OF HOLE  
Dia. (in.) From (ft.) To (ft.)  
Surface 6 1/2 0 163  
7) BOREHOLE COMPLETION:  
 Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval . . . from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)	Gage Casing Screen
						From	To
0	16	SAND					
16	21	Red CLAY	4"	N	PVC	0	148
21	39	Red CLAY	4"	N	PVC Slotted	148	163
39	69	Red CLAY					
69	79	SAND					
79	112	Red CLAY					
112	163	SAND					

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:  
CEMENTING DATA  
Cemented from \_\_\_\_\_ ft. to 20' ft.  
Method used GRAVITY  
Cemented by \_\_\_\_\_  
(Company or Individual)

RECEIVED  
FEB 2 1988

TEXAS WATER COMMISSION

9) WATER LEVEL:  
Static level 112 ft. below land surface Date 4/14/87  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

10) PACKERS: Type FORMATION @ 20' Depth 148'

11) TYPE PUMP:  
 Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 140 ft.

13) WATER QUALITY:  
Did you knowingly penetrate any strata which contained undesirable water?  Yes  No  
If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Was a chemical analysis made?  Yes  No

12) WELL TESTS:  
 Type Test  Pump  Bailer  Jetted  Estimated  
Yield: 12 gpm with 50 ft. drawdown after 3 hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME BALLARD'S Drilling Water Well Driller's License No. 2384  
ADDRESS P.O. Box 2004 (Street or RFD) Millis (City) TX (State) 77378 (Zip)  
(Signed) Charles A. Ballard (Licensed Water Well Driller) (Signed) \_\_\_\_\_ (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 60-13-5 Located on map \_\_\_\_\_

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

ATTENTION OWNER: Confidentiality  
Privilege Notice on Reverse Side

State of Texas  
WELL REPORT

Texas Water Well Drillers Board  
P.O. Box 13087  
Austin, TX 78711-3087  
512-371-6299

1) OWNER Riverside Water Corp. ADDRESS PO Box 194 Riveside Tx. 77367  
(Name) (Street or RFD) (City) (State) (Zip)  
2) LOCATION OF WELL:  
County Walker 11 miles in NE direction from Huntsville  
(NE, SW, etc.) (Town)

Driller must complete the legal description below with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.

LEGAL DESCRIPTION:

Section No. \_\_\_\_\_ Block No. \_\_\_\_\_ Township \_\_\_\_\_ Abstract No. \_\_\_\_\_ Survey Name \_\_\_\_\_  
Distance and direction from two intersecting section or survey lines \_\_\_\_\_

SEE ATTACHED MAP

3) TYPE OF WORK (Check):

New Well  Deepening  
 Reconditioning  Plugging

4) PROPOSED USE (Check):

Domestic  Industrial  Monitor  Public Supply  
 Irrigation  Test Well  Injection  De-Watering

5) DRILLING METHOD (Check):

Mud Rotary  Air Hammer  Jetted  Bored  
 Air Rotary  Cable Tool  Other \_\_\_\_\_

6) WELL LOG: WELL # 2

Date Drilling: 2/3 94  
Started 19  
Completed 2/9 1994

DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
	Surface	
4.5	509	1200

7) BOREHOLE COMPLETION:

Open Hole  Straight Wall  Underreamed  
 Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval ... from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

From (ft.) To (ft.) Description and color of formation material

509-521	sand st
521-621	bl clay
621-631	sand
631-645	sand st
645-648	clay
648-661	sand
661-717	sand st
717-732	bl clay
732-748	sand
748-766	clay

(Use reverse side if necessary)

8) CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	u	bar=weld ss	464	494	10

9) CEMENTING DATA [Rule 287.44(1)]

Cemented from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. No. of Sacks Used \_\_\_\_\_  
\_\_\_\_\_ ft. to \_\_\_\_\_ ft. No. of Sacks Used \_\_\_\_\_

Method used test hole 509 to 1200  
Cemented by cemented off  
Holly Water Wells

13) TYPE PUMP:

Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 419 ft.

14) WELL TESTS:

Type Test:  Pump  Bailer  Jetted  Estimated  
Yield: \_\_\_\_\_ gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

15) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? salt Depth of strata test hole  
Was a chemical analysis made?  Yes  No

10) SURFACE COMPLETION

Specified Surface Slab Installed [Rule 287.44(2)(A)]  
 Specified Steel Sleeve Installed [Rule 287.44(3)(A)]  
 Pitless Adapter Used [Rule 287.44(3)(B)]  
 Approved Alternative Procedure Used [Rule 287.71]

11) WATER LEVEL:

Static level 300+ ft. below land surface Date \_\_\_\_\_  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

12) PACKERS:

Type	Depth
4 X 6 BP	470+ -

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Holly Water Wells WELL DRILLER'S LICENSE NO. 2026/2221  
(Type or print)

ADDRESS 607 HWY 19 Huntsville Tx 77340  
(Street or RFD) (City) (State) (Zip)

(Signed) Henry Lee (Licensed Well Driller) (Signed) \_\_\_\_\_ (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

For TWC use only: Well No. 60135 Located on map \_\_\_\_\_

X

**IMPORTANT NOTICE FOR PERSONS  
HAVING WELLS DRILLED CONCERNING  
PRIVILEGE OF CONFIDENTIALITY**



The Water Well Drillers Board and the Texas Water Commission are concerned that some persons having wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every licensed water well driller drilling, deepening or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within 60 days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. Each copy of a well log, other than a Commission copy, shall include the name, mailing address, and telephone number of the Board and the Commission. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential.

From (ft.)	To (ft.)	Description and color of formation material
766-781		sand st
781-795		clay
795-814		sand
814-821		sand st
821-831		clay
831-841		sand st
841-850		clay
850-861		sand
861-906		bl clay
906-916		sand st
916-927		sand
927-975		bl clay
975-981		sand
981-1001		sand st
1001-1006		clay
1006-1029		sand
1029-1037		sand st
1037-1038		rock
1038-1056		sand
1056-1057		rock
1057-1101		sand
1101-1106		clay
1106-1121		sand
1121-1133		clay
1133-1156		sand
1156-1161		sand st
1161-1200		sand





### LEGEND

	NATIONAL OR STATE BOUNDARY
	COUNTY BOUNDARY
	CITY LIMIT
	RAILROAD AND STATION
	PRIVATE ROAD
	BLADED EARTH ROAD
	GRAVEL SURFACED ROAD
	PAVED ROAD - LOW TYPE
	PAVED ROAD - HIGH TYPE
	DIVIDED ROADWAY
	ROAD IN CITY OR INSET
	FRONTAGE ROADS
	FEDERAL AID INTERSTATE ROUTE
	FEDERAL AID PRIMARY ROUTE
	FEDERAL AID SECONDARY ROUTE
	FEDERAL AID URBAN ROUTE
	MILEAGE BETWEEN POINTS
	INTERSTATE HIGHWAY
	U.S. NUMBERED HIGHWAY
	STATE HIGHWAY - LOOP OR SPUR
	STATE HIGHWAY - PARK ROAD
	FARM OR RANCH TO MARKET ROAD
	RECREATIONAL ROAD
	MULTIPLE U.S. HIGHWAY ROUTE
	BUSINESS OR INDUSTRY
	FACTORY OR INDUSTRIAL HOTEL OR MOTEL
	POST OFFICE AND BUSINESS
	GRAIN ELEVATOR
	DRIVE IN THEATRE
	COMMUNITY OR TOWN HALL
	CLUB HOUSE
	CHURCH
	DWELLING
	CEMETERY
	CAMP OR LODGE
	SAWMILL
	WATER TANK
	PUMPING STATION
	TRANSMISSION TOWER
	MINING QUARRY OR GRAVEL PIT
	S.D.H.A.P. DISTRICT OFFICE
	POWER SUB STATION
	POWER PLANT
	AUTO JUNKYARD
	GARBAGE AND RUBBISH DUMP
	SCRAP METAL
	FEED LOT
	SEWAGE TREATMENT PLANT
	TRAILER PARK
	RECREATIONAL FACILITY
	GOLF COURSE OR COUNTRY CLUB
	FAIR GROUND OR RODEO ARENA

1944

1944

1944