

#6 UNKRR

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

For TDWR use only Well No. 60-20-9E Located on map YES Received: C.F.S.

1) OWNER Jim Godfrey Address Rt. 1 Box 491 Point Blank, Texas 77364
2) LOCATION OF WELL: County Walker 3 miles in S direction from Huntsville

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map. map on 60-13-6E

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Domestic Industrial Public Supply Irrigation Test Well Other
5) DRILLING METHOD (Check): Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG: Date drilled 1-24-83 DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 169
7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval . . . from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mgf., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include 0-2 top soil, 2-18 meally clay, 18-35 sand, 35-62 meally clay, 62-70 sand, 70-82 sand streaks, 82-113 brown clay, 113-122 sand, 122-131 meally clay, 131-169 sand.

CEMENTING DATA Cemented from 148 ft. to 100 ft. Method used Pressure Cemented by Henry Lee (Company or Individual)

9) WATER LEVEL: Static level ft. below land surface Date Artesian flow gpm. Date

RECEIVED APR 13 1983 DEPT. OF WATER RESOURCES (Use reverse side if necessary)

10) PACKERS: Type Depth Lead L 143

11) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 140 ft.

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? Yes No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water? Good Depth of strata 38 ft. Was a chemical analysis made? Yes No

12) WELL TESTS: Type Test Pump Bailer Jetted Estimated Yield: 20 gpm with ft. drawdown after hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME RALPH A. CADWALLADER, Henry Lee Water Well Drillers Registration No. 2026, 2221 ADDRESS P.O. Box 638 Riverside, Texas 77367 (Signed) [Signature] Holly Water Wells (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

“Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record.”

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term “Commission” in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

© 1984 by the State of Texas
Department of Water Resources
Austin, Texas 78711

Walker #33

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER Seventh Day Adventist Address P.O. Box 1863 Huntsville, TX 77340

2) LOCATION OF WELL: County Walker 1 miles in S direction from Huntsville

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines See attached map. 60-20-4P

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Public Supply Irrigation Test Well Other 5) DRILLING METHOD (Check): Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG: Date drilled 4/27/84 DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 180 7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other If Gravel Packed give interval ... from ft. to ft.

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From To, Gage Casing Screen. Rows include Top soil, Red clay, Sand, Sand streaks, Sand, Brown clay, Sand streaks & Meally clay, Rock, Meally clay & rock streaks, Blue clay, Sand.

8) CASING, BLANK PIPE, AND WELL SCREEN DATA: CEMENTING DATA Cemented from 168 ft. to 68 ft. Method used Pressure Cemented by Henry Lee (Company or Individual)

9) WATER LEVEL: Static level 58 ft. below land surface Date 4-30-84 Artesian flow gpm. Date

10) PACKERS: Type Depth Lead L 163

11) TYPE PUMP: Turbine Jet Submersible Cylinder Other Depth to pump bowls, cylinder, jet, etc., 160 ft.

12) WELL TESTS: Type Test: Pump Bailer Jetted Estimated Yield: 20 gpm with ft. drawdown after hrs. 13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water: good Depth of strata 31 Ft. Was a chemical analysis made? No

RECEIVED JUL-6-1984 DEPT. OF WATER RESOURCES

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well service Water Well Driller's License No. 2026/2221 ADDRESS Rt. 11 Box 607 Huntsville, TX 77340

(Signed) [Signature] (Licensed Water Well Driller) (Signed) [Signature] (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 60-20-4E Located on map 460MM

Dup

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

10-17-74
10:30 AM
CITY
10-17-74

#6 WALKER

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

For TDWR use only Well No. 60-20-9D Located on map Yes Received: e.f.s.

1) OWNER Thomas W. Dorrell Address 26947 Hwy. 75 Spring, Texas 77373

2) LOCATION OF WELL: County Walker 4 miles in South direction from Huntsville

Driller must complete the legal description to the right with distance and direction from two intersecting section or survey lines, or he must locate and identify the well on an official Quarter- or Half-Scale Texas County General Highway Map and attach the map to this form.

Legal description:

Section No. Block No. Township

Abstract No. Survey Name

Distance and direction from two intersecting section or survey lines

See attached map. 60-21-SR

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging

4) PROPOSED USE (Check): Domestic Industrial Public Supply Irrigation Test Well Other

5) DRILLING METHOD (Check): Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other

6) WELL LOG: Date drilled 1-7-81

Table with columns: Dia. (in.), From (ft.), To (ft.), Surface, 6 1/2, 235

7) BOREHOLE COMPLETION: Open Hole Straight Wall Underreamed Gravel Packed Other

Table with columns: From (ft.), To (ft.), Description and color of formation material

Table with columns: Dia. (in.), New or Used, Steel, Plastic, etc., Setting (ft.), Gage Casing Screen

8) CASING, BLANK PIPE, AND WELL SCREEN DATA: CEMENTING DATA

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? Type of water? Good Depth of strata 40

9) WATER LEVEL: Static level 145 ft. below land surface Date 1-8-81

10) PACKERS: Rubber R&R 211

11) TYPE PUMP: Submersible Depth to pump bowls, cylinder, jet, etc., 200 ft.

12) WELL TESTS: Type Test Pump Bailer Jetted Estimated Yield: 25 gpm with ft. drawdown after hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME RALPH A. CADWALLADER Water Well Drillers Registration No. 2026

ADDRESS P.O. Box 638 Riverside, Texas 77367

(Signed) Ralph A. Cadwallader Holly Water Well Service (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

RECEIVED

JUL 14 1982

CR/TDW

RECEIVED
MAR 17 1981
DEPT. OF
WATER RESOURCES

STATE

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-20-9C Located on map 1/2 5 Received: 7-5-75

1) OWNER: Person having well drilled KING CHANDLER Address 85 S. SAM HOUSTON HUNTSVILLE, TEXAS Landowner SAME Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County WALKER 5 miles in S direction from HUNTSVILLE (Town) Locate by sketch map showing landmarks, roads, hiway number, etc.* SOUTHWOOD DR. Well North HY 75

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging 4) PROPOSED USE (Check): Domestic Industrial Municipal Irrigation Test Well Other 5) TYPE OF WELL (Check): Rotary Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 6 1/2 in. Depth drilled 544 ft. Depth of completed well 544 ft. Date drilled 10-1-75 All measurements made from 0 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-42 RED + WHITE CLAY, 42-102 SAND, 102-160 WHITE CLAY, 160-177 SAND, 177-179 HARD CLAY, 179-189 SAND, 189-341 WHITE CLAY, 341-370 SANDY CLAY, 370-380 SAND, 380-521 BROWN CLAY, 521-544 SAND.

9) Casing: Type: Old New Steel Plastic Other Cemented from 524 ft. to 450 ft. Diameter (inches) 4 Setting From (ft.) 524 To (ft.) 71 Gage SCH 40

10) SCREEN: Type STAINLESS STEEL Perforated Slotted Diameter (inches) 2 1/2 Setting From (ft.) 524 To (ft.) 544 Slot Size # 8

7) COMPLETION (Check): Straight wall Gravel packed Other Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: gpm with ft. drawdown after hrs. Bailer test gpm with ft. drawdown after hrs. Artesian flow gpm Temperature of water

8) WATER LEVEL: Static level 170 ft. below land surface Date Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., 320 ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? GOOD depth of strata 24

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME E.A. HOLLY (Type of Print) Water Well Drillers Registration No. 801 ADDRESS Box 37 RIVERSIDE TEXAS 77367 (Signed) E.A. Holly (Water Well Driller) E.A. HOLLY COMPANY (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED
JAN 20 1976
TEXAS WATER DEVELOPMENT BOARD

RECEIVED
OCT 10 1975
TEXAS WATER DEVELOPMENT BOARD

#3 WA

Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas WATER WELL REPORT ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

Texas Water Well Drillers Board P. O. Box 13087 Austin, Texas 78711

1) OWNER Paul Nelson Address 8989 Westheimer Suite 309, Houston 77063

2) LOCATION OF WELL: County WALKER 1 miles in S direction from HUNTSVILLE

Legal description: Section No. Block No. Township Abstract No. Survey Name Distance and direction from two intersecting section or survey lines

See attached map. Map 60-20-6P

3) TYPE OF WORK (Check): New Well, Deepening, Reconditioning, Plugging 4) PROPOSED USE (Check): Domestic, Industrial, Public Supply, Irrigation, Test Well, Other 5) DRILLING METHOD (Check): Mud Rotary, Air Hammer, Driven, Bored, Air Rotary, Cable Tool, Jetted, Other

6) WELL LOG: Date drilled 7/5/84 DIAMETER OF HOLE Dia. (in.) From (ft.) To (ft.) 6 1/2 Surface 205 7) BOREHOLE COMPLETION: Open Hole, Straight Wall, Underreamed, Gravel Packed, Other

Table with 5 columns: From (ft.), To (ft.), Description and color of formation material, Dia. (in.), New or Used, Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial, Setting (ft.) From, To, Gage Casing Screen

8) CASING, BLANK PIPE, AND WELL SCREEN DATA: CEMENTING DATA Cemented from 193 ft. to 93 ft. Method used Pressure Cemented by Henry Lee

9) WATER LEVEL: Static level ft. below land surface Date Artesian flow gpm. Date

10) PACKERS: Type Depth Lead L 189

11) TYPE PUMP: Turbine, Jet, Submersible, Cylinder, Other Depth to pump bowls, cylinder, jet, etc., 180 ft.

12) WELL TESTS: Type Test, Pump, Bailer, Jetted, Estimated Yield: gpm with ft. drawdown after hrs.

RECEIVED OCT 15 1984 DEPT. OF WATER RESOURCES

13) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable water? No If yes, submit "REPORT OF UNDESIRABLE WATER" Type of water? good Depth of strata 19 Ft. Was a chemical analysis made? No

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

COMPANY NAME Holly Water Well Service Water Well Driller's License No. 2026/2221 ADDRESS Rt. 11 Box 607 Huntsville, TX 77340 (Signed) [Signature] (Signed) [Signature]

Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 60-20-9C Located on map res.c.f.s.

**IMPORTANT NOTICE FOR PERSONS
HAVING WELLS DRILLED CONCERNING
PRIVILEGE OF CONFIDENTIALITY**

The Water Well Drillers Board and the Department of Water Resources are concerned that some persons having water wells drilled may not be aware of the confidentiality privilege provision of Section 5 of the Water Well Drillers Act. Section 5, the Reporting of Well Logs, reads as follows:

"Every registered water well driller drilling, deepening, or otherwise altering a water well within this State shall make and keep, or cause to be made and kept, a legible and accurate well log, and within sixty (60) days from the completion or cessation of drilling, deepening or otherwise altering such a water well, shall deliver or transmit by certified mail a copy of such well log to the Commission, and the owner thereof or the person having had such well drilled. The well log required herein shall at the request in writing to the Commission, by certified mail, by the owner or the person having such well drilled be held as confidential matter and not made of public record."

The last sentence specifies the means whereby you can, if you wish, assure that logs of your wells will be kept confidential. Please note that the term "Commission" in the above-quoted section and elsewhere in the Water Well Drillers Act now properly means the Texas Department of Water Resources (P. O. Box 13087; Austin, Texas 78711).

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711

State of Texas
WATER WELL REPORT

For TWDB use only
Well No. 60-20-9B
Located on map 40-5
Received: 74
dlr

1) OWNER:
Person having well drilled Dorothy Templeton Address 1817 W. 14th Houston Tex
(Name) (Street or RFD) (City) (State)
Landowner _____ Address _____
(Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:
County Walker, 9 miles in N direction from New Waverly
(Town)
Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*
Give legal location with distances and directions from adjacent sections or survey lines.
Labor _____ League _____
Block _____ Survey _____
Abstract No. _____
(NW¼ NE¼ SW¼ SE¼) of Section _____

(Use reverse side if necessary)

3) TYPE OF WORK (Check):
New Well Deepening _____
Reconditioning _____ Plugging _____
4) PROPOSED USE (Check):
Domestic Industrial _____ Municipal _____
Irrigation _____ Test Well _____ Other _____
5) TYPE OF WELL (Check):
Rotary Driven _____ Dug _____
Cable _____ Jetted _____ Bored _____

6) WELL LOG:
Diameter of hole 6 1/2 in. Depth drilled 350 ft. Depth of completed well 350 ft. Date drilled 8-28-73
All measurements made from _____ ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material	9) Casing: Type: Old _____ New <input checked="" type="checkbox"/> Steel _____ Plastic <input checked="" type="checkbox"/> Other _____ Cemented from <u>200</u> ft. to <u>335</u> ft.
0	24	Sand + clay	Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Gage _____
24	70	Hard Clay	<u>4</u> <u>0</u> <u>335</u>
70	90	SAND	
90	110	Clay	
110	120	SAND	
120	185	Clay	
185	205	Rock + Clay	
205	305	Broken Rock + Clay	
305	335	Hard Clay	
335	350	Water sand	<u>2 1/2</u> <u>340</u> <u>350</u> <u>2 1/2</u> PIPE <u>9</u>

7) COMPLETION (Check):
Straight wall Gravel packed _____ Other _____
Under reamed _____ Open Hole _____
8) WATER LEVEL:
Static level 124 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____
Depth to pump bowls, cylinder, jet, etc., 189 ft. below land surface.
11) WELL TESTS:
Was a pump test made? Yes _____ No If yes, by whom? _____
Yield: 50 gpm with AIR ft. drawdown after _____ hrs.
Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
Artesian flow _____ gpm
Temperature of water _____
12) WATER QUALITY:
Was a chemical analysis made? Yes _____ No
Did any strata contain undesirable water? Yes _____ No
Type of water? H1 Ph depth of strata 15

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.
NAME Patterson Water Wells Water Well Drillers Registration No. 182
(Type or Print)
ADDRESS 109 N. Magnolia Conroe Tex
(Street or RFD) (City) (State)
(Signed) L.M. Patterson _____
(Water Well Driller) (Company Name)
Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

TEXAS WATER DEVELOPMENT BOARD

JAN 2 1974

RECEIVED

RECEIVED

APR 11 1974

Central Records
Texas Water Development Board

Send original copy by certified mail to the Texas Water Development Board P. O. Box 13087 Austin, Texas 78711


State of Texas

WATER WELL REPORT

For TWDB use only
Well No. 60-20-9A
Located on map 7c-5
Received: 2-7-73
Prusa

1) OWNER:
Person having well drilled BILLY ROBERTS (Name) Address HY 75 - S. HONTSVILLE TEXAS (Street or RFD) (City) (State)
Landowner SAME (Name) Address _____ (Street or RFD) (City) (State)

2) LOCATION OF WELL:
County WALKER, 3 miles in S direction from HONTSVILLE (N.E., S.W., etc.) (Town)



Give legal location with distances and directions from adjacent sections or survey lines.
Labor _____ League _____
Block _____ Survey _____
Abstract No. _____
(NW¼ NE¼ SW¼ SE¼) of Section _____

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check):
 Domestic Industrial Municipal Irrigation Test Well Other
5) TYPE OF WELL (Check):
 Rotary Driven Dug Cable Jetted Bored

6) WELL LOG:
Diameter of hole 6½ in. Depth drilled 217 ft. Depth of completed well 217 ft. Date drilled 12-5-72
All measurements made from _____ ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0	10	RED CLAY
10	32	BROWN SAND
32	82	WHITE CLAY
82	106	SAND WITH CLAY BRKS
106	202	WHITE CLAY
202	217	WHITE SAND

9) Casing:
Type: Old New Steel Plastic Other _____
Cemented from _____ ft. to _____ ft.
Diameter (inches) 4 Setting From (ft.) 204 To (ft.) 150 Gage SC# 40

10) SCREEN:
Type STAINLESS STEEL
Perforated Slotted
Diameter (inches) 2½ Setting From (ft.) 207 To (ft.) 217 Slot Size # 8

7) COMPLETION (Check):
 Straight wall Gravel packed Other _____
 Under reamed Open Hole

11) WELL TESTS:
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.
Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
Artesian flow _____ gpm
Temperature of water _____

8) WATER LEVEL:
Static level 139 ft. below land surface Date 12-5-72
Artesian pressure _____ lbs. per square inch Date _____
Depth to pump bowls, cylinder, jet, etc., 190 ft. below land surface.

12) WATER QUALITY:
Was a chemical analysis made? Yes No
Did any strata contain undesirable water? Yes No
Type of water? Good depth of strata _____

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.
NAME F. A. HOLLY (Type or Print) Water Well Drillers Registration No. 801
ADDRESS Box 37 RIVERSIDE TEXAS (Street or RFD) (City) (State)
(Signed) F. A. HOLLY (Water Well Driller) F. A. HOLLY CO (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area, e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-GW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

RECEIVED
MAR 23 1973
Central Records
Texas Water Development Board

TEXAS WATER
DEVELOPMENT BOARD

JAN 19 1973

RECEIVED

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

State of Texas
WELL REPORT

Texas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

1) OWNER MR. BARNES (Name) ADDRESS P.O. Box 1328 Huntsville TX 77342 (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County WAKER (Street, RFD or other) HWY 75 South Huntsville TX (City) (State) (Zip) GRID # 60-20-9

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

6) WELL LOG:
Date Drilling: _____
Started 6/23 1996
Completed 6/24 1996

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
	Surface	
<u>6 1/2</u>	<u>0</u>	<u>120</u>

7) DRILLING METHOD (Check): Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

From (ft.)	To (ft.)	Description and color of formation material
<u>0</u>	<u>1 1/2</u>	<u>Top soil</u>
<u>1 1/2</u>	<u>9</u>	<u>RED CLAY</u>
<u>9</u>	<u>26</u>	<u>SAND</u>
<u>26</u>	<u>35</u>	<u>WHITE CLAY</u>
<u>35</u>	<u>60</u>	<u>SAND</u>
<u>60</u>	<u>95</u>	<u>Broken Rock & Clay</u>
<u>95</u>	<u>120</u>	<u>SAND</u>

8) Borehole Completion (Check): Open Hole Straight Wall
 Underreamed Gravel Packed Other _____
If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
<u>4</u>	<u>N</u>	<u>PVC</u>	<u>0</u>	<u>100</u>	
<u>4</u>	<u>N</u>	<u>PVC Slotted</u>	<u>100</u>	<u>120</u>	<u>899.</u>

13) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet, etc., 82 ft.

9) CEMENTING DATA [Rule 338.44(1)]
Cemented from 0 ft. to 60 ft. No. of sacks used 10
ft. to _____ ft. No. of sacks used _____
Method used Tremie Pipe
Cemented by _____
Distance to septic system field lines or other concentrated contamination 150 ft.
Method of verification of above distance MEASURED

14) WELL TESTS:
Type test: Pump Bailer Jetted Estimated
Yield: 30 gpm with 30 ft. drawdown after 2 hrs.

10) SURFACE COMPLETION
 Specified Surface Slab Installed [Rule 338.44(2)(A)]
 Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
 Pitless Adapter Used [Rule 338.44(3)(b)]
 Approved Alternative Procedure Used [Rule 338.71]

15) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata _____
Was a chemical analysis made? Yes No

11) WATER LEVEL:
Static level 40 ft. below land surface Date 6/26/96
Artesian flow _____ gpm. Date _____

12) PACKERS: Type Depth
2 - 4x6 1/2 FORMATION 60

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME BARNARD WATER WELL CO (Type or print) WELL DRILLER'S LICENSE NO. 2384 W.I.
ADDRESS P.O. Box 3004 WILKINSON TEXAS 77378 (Street or RFD) (City) (State) (Zip)
(Signed) Charles A. Ballard (Licensed Well Driller) (Signed) _____ (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

