

ATTENTION OWNER: Confidentiality
Privilege Notice on reverse side
of Well Owner's copy (pink)

State of Texas WELL REPORT

Texas Department of Licensing &
Regulation
P.O. Box 12157
Austin, TX 78711
512-463-7880

1) OWNER Joe McDaniel ADDRESS 4827 Misty Shadows Houston, Tx 77041
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL'S LOCATION: County Walker 389 Walker Loop Huntsville, Tx Long. _____ Lat. _____
(Street, RFD or other) (City) (State) (Zip) Grid # 60-27-2

3) TYPE OF WORK (Check):
 New Well Deepening
 Reconditioning Plugging

4) PROPOSED USE (Check): Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

6) WELL LOG:
Date Drilling: _____
Started 8-17 19 00
Completed 8-18 ~~19~~ 2000

DIAMETER OF HOLE		
Dia. (in.)	From (ft.)	To (ft.)
7	Surface	147

7) DRILLING METHOD (Check): Driven
 Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

From (ft.)	To (ft.)	Description and color of formation material
0-5		TOP soil
5-80		Clay
80-81		Rock
81-86		Sand
86-120		Clay
120-147		subd
(Use reverse side of Well Owner's copy, if necessary)		

8) Borehole Completion (Check): Open Hole Straight Wall
 Underreamed Gravel Packed Other _____
If Gravel Packed give interval from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC	0	130	40
2	N	PVC	125	130	40
2	N	PVC SLOTT	130	147	#10

13) Well plugged within 48 hours

Casing left in well:		Cement/bentonite placed in well:		Sacks used:
From (ft)	To (ft)	From (ft)	To (ft)	

9) CEMENTING DATA
Cemented from 130 ft. to 30 ft. No. of sacks used 5
0 ft. to 10 ft. No. of sacks used 6
Method used Pressure
Cemented by Vernon Gray
Distance to septic system field lines or other concentrated contamination 105 ft.
Method of verification of above distance Tap

14) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bows, cylinder, jet, etc., 100 ft.

10) SURFACE COMPLETION
 Specified Surface Slab Installed
 Specified Steel Sleeve Installed
 Pileless Adapter Used
 Approved Alternative Procedure Used

15) WELL TESTS:
Type test: Pump Bailer Jetted Estimated
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.

11) WATER LEVEL:
Static level 69 ft. below land surface Date 8-18-00
Artesian flow _____ gpm. Date _____

16) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata 27
Was a chemical analysis made? Yes No

12) PACKERS: Rubber Type K Depth 125

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Gray's Water Well Service WELL DRILLER'S LICENSE NO. 2011 Wpk
(Type or print)

ADDRESS P.O. Box 1788 Trinity, Texas 75862
(Street or RFD) (City) (State) (Zip)

(Signed) Vernon Gray (Signed) _____
(Licensed Well Driller) (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

Email address: water.well@license.state.tx.us

WELL REPORT

1) WELL IDENTIFICATION AND LOCATION DATA

1) OWNER

Name	Address	City	State	Zip
Clyde Fendley	124 Sandy Creek Nursery Rd.	Huntsville	Texas	77340

2) WELL LOCATION

County	Physical Address	City	State	Zip
Walker	124 Sandy Creek Nursery Rd.	Huntsville	Texas	77340

3) Type of Work

New Well Deepening
 Reconditioning

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

5) N↑

6) Drilling Date
Started 8 / 22 / 00
Completed 8 / 25 / 00

7) Drilling Method (check) Driven Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

Diameter of Hole		
Dia. (in)	From (ft)	To (ft)
10"	0	10'
6 3/4	10'	100'
3 7/8	100'	127'

From (ft)	To (ft)	Description and color of formation material	8) Borehole Completion																										
0-6	87-90	Sand shale	<input type="checkbox"/> Open Hole <input checked="" type="checkbox"/> Straight Wall <input type="checkbox"/> Under-reamed <input type="checkbox"/> Gravel Packed <input type="checkbox"/> Other _____ If Gravel Packed give the interval from _____ ft. to _____ ft.																										
6-17	90-98	clay	Casing, Blank Pipe, and Well Screen Data <table border="1"> <thead> <tr> <th rowspan="2">Dia. (in.)</th> <th rowspan="2">New Or Used</th> <th rowspan="2">Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg., if commercial</th> <th colspan="2">Setting (ft)</th> <th rowspan="2">Gage Casing Screen</th> </tr> <tr> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>4</td> <td>N</td> <td>PVC</td> <td>0</td> <td>100</td> <td>#40</td> </tr> <tr> <td>2</td> <td>N</td> <td>PVC</td> <td>86</td> <td>107</td> <td>#40</td> </tr> <tr> <td>2</td> <td>N</td> <td>PVC Screen</td> <td>107</td> <td>127</td> <td>#16</td> </tr> </tbody> </table>	Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen	From	To	4	N	PVC	0	100	#40	2	N	PVC	86	107	#40	2	N	PVC Screen	107	127	#16
Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg., if commercial					Setting (ft)			Gage Casing Screen																			
				From	To																								
4	N	PVC		0	100	#40																							
2	N	PVC		86	107	#40																							
2	N	PVC Screen		107	127	#16																							
17-30	98-127	Sand																											
30-45		clay																											
45-52		Sand																											
52-60		clay																											
60-66		Gravel																											
66-75		clay																											
75-85		Sandy shale																											
85-87		Rock																											

(Use reverse side of Well Owner's copy, If necessary)

13) Plugged Well plugged within 48 hours
Casing left in well: _____ Cement/Bentonite placed in well: _____

From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

9) Cementing Data
Cementing from 100 ft. to 10 ft. # of sacks used 5
0 ft. to 10 ft. # of sacks used 8
Method Used pressure
Cementing By Richard McKee
Distance to septic system field or other concentrated contamination N/A ft.
Method of verification of above distance None

14) Typepump Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet etc. 80 ft.

10) Surface Completion
 Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

15) Water Test
Type test Pump Bailer Jetted Estimated
Yield: 60 gpm with _____ ft. drawdown after _____ hrs.

11) Water Level
Static level 32 ft. below Date 8/25/00
Artesian Flow ICE # gpm. Date / /

16) Water Quality
Did you knowingly penetrate and strata which contain undesirable constituents.
 YES NO If yes, did you submit a REPORT OF UNDESIRABLE WATER
Type of water good Depth of Strata 29'
Was a chemical analysis made Yes No

12) Packers Rubber Type K SEQ # _____ Depth 86'

EMP # _____
DEC 01 2000
DISC CO
COMMENT

Company or individual's Name (type or print) Gray's Water Well Service

Address P.O. Box 1788 City Trinity State Texas Zip 75862

Signature Vernon Gray Date _____ Signature Richard McKee Date 8/28/00

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157 Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

Email address: water.well@license.state.tx.us

WELL REPORT

1) WELL IDENTIFICATION AND LOCATION DATA

1) OWNER

Name	Address	City	State	Zip
Sandy Creek Nursery	124 Sandy Creek Nursery	Huntsville	Tx	77340

2) WELL LOCATION

County	Physical Address	City	State	Zip
Walker	124 Sandy Creek Nursery Rd.	Huntsville	Tx	77340

3) Type of Work

New Well Deepening
 Reconditioning

4) Proposed Use (check) Monitor Environmental Soil Boring Domestic
 Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

5) Monitor Environmental Soil Boring Domestic Industrial Irrigation Injection Public Supply De-watering Testwell

6) Drilling Date

Started 4/24/01
Completed 4/25/01

7) Drilling Method (check) Driven Air Rotary Mud Rotary Bored
 Air Hammer Cable Tool Jetted
 Other _____

Diameter of Hole

Dia. (in)	From (ft)	To (ft)
10"	0	10'
6 3/4"	10'	105'
3 7/8"	105'	135'

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____
If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
4 1/2"	N	PVC	0	105'	+40
2"	N	PVC	180'	105'	+40
2"	N	PVC Screen	105'	135'	+10

9) Cementing Data
Cementing from 105 ft. to 0 ft. # of sacks used 5
0 ft. to 10 ft. # of sacks used 7
Method Used pressure
Cementing By Richard McKee
Distance to septic system field or other concentrated contamination 1/2 ft.
Method of verification of above distance No Lines or Tanks

13) Plugged Well plugged within 48 hours
Casing left in well: Cement/Bentonite placed in well:

From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

14) Typepump Turbine Jet Submersible Cylinder
 Other _____
Depth to pump bowls, cylinder, jet etc., 100 ft.

15) Water Test
Type test Pump Bailer Jetted Estimated
Yield: 75 gpm with _____ ft. drawdown after _____ hrs.

16) Water Quality
Did you knowingly penetrate and strata which contain undesirable constituents.
 YES NO If yes, did you submit a REPORT OF UNDESIRABLE WATER
Type of water good Depth of Strata 32'
Was a chemical analysis made Yes No

10) Surface Completion
 Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

11) Water Level
Static level 60 ft. below Date 4/25/01
Artesian Flow _____ gpm. Date _____

12) Packers

FILE ID	Type	SEQ #
Rubber	K	100
EMP #		DESC #

JUN 04 2001

Company or individual's Name (type or print) Gray's Water Well

Address PO Box 1784 City TRINITY State TX Zip 75786

Signature Vernon Gray Date 5/1/01 Signature Richard McKee Date 5/1/01

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

State of Texas
WELL REPORT

Texas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

1) OWNER Joe M. Daniel (Name) ADDRESS: 4827 Misty Shadow Ln. (Street or RFD) Waco (City) TX (State) 77041 (Zip)

2) ADDRESS OF WELL: County Walker Walker Loop (Street or RFD) Huntsville (City) TX (State) 77340 (Zip) GRID # 60 27 2

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Monitor Environmental Soil Boring Domestic Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

6) WELL LOG: Date Drilling: Started 7-29 1996 Completed 7-30 1996
DIAMETER OF HOLE: Dia. (in.) From (ft.) To (ft.)
6 3/4 Surface 90
3 7/8 90 105
7) DRILLING METHOD (Check): Driven Air Rotary Mud Rotary Bored Air Hammer Cable Tool Jetted Other

8) Borehole Completion (Check): Open Hole Straight Wall Underreamed Gravel Packed Other
If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
4	N	PVC	0	90	#40
2	N	PVC	85	95	#40
2	N	PVC Screen	95	105	#10

9) CEMENTING DATA [Rule 338.44(1)] 100%
Cemented from 90 ft. to 0 ft. No. of sacks used 5
0 ft. to 10 ft. No. of sacks used 7
Method used pressure
Cemented by Richard Mike
Distance to septic system field lines 300 ft.
Method of verification of above distance Tape

13) TYPE PUMP: Turbine Jet Submersible Cylinder Other
Depth to pump bowls, cylinder, jet, etc., 90 ft.

14) WELL TESTS: Type test: Pump Bailer Jetted Estimated
Yield: 30 gpm with _____ ft. drawdown after _____ hrs.

15) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? good Depth of strata 15
Was a chemical analysis made? Yes No

10) SURFACE COMPLETION: Specified Surface Slab Installed [Rule 338.44(2)(A)] Specified Steel Sleeve Installed [Rule 338.44(3)(A)] Pitless Adapter Used [Rule 338.44(3)(b)] Approved Alternative Procedure Used [Rule 338.71]
11) WATER LEVEL: Static level 57 ft. below land surface Date 7-30-96
Artesian flow _____ gpm. Date _____

12) PACKERS: Rubber Type K Depth 85

FILE ID	Type	Depth	SEC #
<u>EMPH</u>	<u>K</u>	<u>85</u>	

SEP 05 1997

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true and correct to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME Greys Water Well (Type or print) WELL DRILLER'S LICENSE NO. 2011 WPK
ADDRESS PO Box 1788 TRINITY TX. 75862 (Street or RFD) (City) (State) (Zip)
(Signed) Vernon Gray (Licensed Well Driller) (Signed) Richard Mike (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available.

ATTENTION OWNER: Confidentiality
Privilege Notice on Reverse Side

STATE OF TEXAS
WATER WELL REPORT

1) OWNER: GARY & CHRIS SMITH ADDRESS: FM 1791 CITY: HUNTSVILLE STATE: TX ZIP: -

2) ADDRESS OF WELL: 5)
County: WALKER GRID #
Street or RFD: NORTH OF HUNTSVILLE
City, State, Zip code: HUNTSVILLE, TX

3) TYPE OF WORK: NEW WELL 4) PROPOSED USE: DOMESTIC
If Public Supply well, were plans submitted to the TNRCC?

6) WELL LOG: 02307 DIAMETER OF HOLE 7) DRILLING METHOD: 8) BOREHOLE COMPLETION:
DATE DRILLING: DIAMETER FROM TO MUD ROTARY STRAIGHT WALL N
STARTED: 02/29/96 6 3/4 0 345 IF GRAVEL... FROM FT. TO FT.
COMPLETED: 4 1/2 345 362 FROM FT. TO FT.

60-27-2

CASING, BLANK PIPE, AND WELL SCREEN DATA:

DIA	NEW/USED	DESCRIPTION	FROM	TO	GAGE CASING SCREEN
4	N	PVC	0	345	SCH 40
2.5	N	GALV.	339	350	SCH 40
2.5	N	RBSS	350	360	10 GA
2.5	N	DOWN HOLE ASSEMBLY	360	362	SCH 40

GEOLOGICAL DESCRIPTION:

FROM	TO	DESCRIPTION
0	18	CLAY
18	24	SAND
24	77	CLAY
77	84	SANDY CLAY
84	149	SAND OTHER
149	157	CLAY SAND
157	187	SAND
187	235	CLAY
235	251	SAND
251	288	CLAY
288	312	SAND
312	315	CLAY
315	361	SAND
361	362	CLAY

RECEIVED
AUG 02 1996
TEXAS NATURAL RESOURCE
CONSERVATION COMMISSION

9) CEMENTING DATA:
Cemented from No. of Sacks Used
0 FT. TO 339 FT. 34
FT. TO FT.
Method used: PRESSURE
Cemented by: WEISINGER WATER WELL
Distance to septic field lines: ft.
Method of verification of above distance:

10) SURFACE COMPLETION:
APP. ALTER. PROCD.

11) WATER LEVEL:
STATIC LEVEL : 77 FT. DATE:
ARTESIAN FLOW: GPM. DATE:

12) PACKERS: TYPE DEPTH
BP SEAL 339

13) TYPE PUMP: SUBMERSIBLE DEPTH TO PUMP:
14) WELL TEST: JETTED YIELD: 100 GPM WITH FT DRAWDOWN AFTER HRS

15) WATER QUALITY: TYPE OF WATER: EXCELLENT DEPTH OF STRATA: NO CHEMICAL ANALYSIS MADE
NO STRATA OF UNDESIRABLE WATER PENETRATED

COMPANY NAME: WEISINGER WATER WELL, INC WATER WELL DRILLER'S LICENSE NO.: 1541,1991,&1992 FOR TWC USE ONLY
ADDRESS: 2200 EAST DAVIS CITY: CONROE STATE: TX ZIP CODE: 77301 WELL NO. _____
LOCATED ON MAP _____

I HEREBY CERTIFY THAT THIS WELL WAS DRILLED BY ME (OR UNDER MY SUPERVISION) AND THAT EACH AND ALL OF THE STATEMENTS HEREIN ARE TRUE TO THE BEST OF MY KNOWLEDGE AND BELIEF. I UNDERSTAND THAT FAILURE TO COMPLETE ITEMS 1 THRU 15 WILL RESULT IN THE LOG(S) BEING RETURNED FOR COMPLETION AND RESUBMITTAL.

(signed) John E. Weisinger (signed) _____
(LICENSED WATER WELL DRILLER)

(REGISTERED DRILLER TRAINEE)

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas
WATER WELL REPORT

For TWDB use only
Well No. 60-27-2B
Located on map 75/25
Received dlb

1) OWNER:
Person having well drilled CHARLIE POWELL Address RT 2 HUNTSVILLE TEX
(Name) (Street or RFD) (City) (State)
Landowner " Address " (City) (State)

2) LOCATION OF WELL:
County WALKER, 12 miles in W direction from HUNTSVILLE
(N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*

OVER
North
↑
(Use reverse side if necessary)

or Give legal location with distances and directions from adjacent sections or survey lines.
Labor _____ League _____
Block _____ Survey _____
Abstract No. _____
(NW¼ NE¼ SW¼ SE¼) of Section _____

3) TYPE OF WORK (Check):
New Well Deepening _____
Reconditioning _____ Plugging _____
4) PROPOSED USE (Check):
Domestic Industrial _____ Municipal _____
Irrigation _____ Test Well _____ Other _____
5) TYPE OF WELL (Check):
Rotary Driven _____ Dug _____
Cable _____ Jetted _____ Bored _____

6) WELL LOG:
Diameter of hole 6 3/4 in. Depth drilled 160 ft. Depth of completed well 160 ft. Date drilled FEB 74
All measurements made from 1 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
0-1		surface
1-28		clay
28-31		sand
31-130		clay
130-160		sand

9) Casing:
Type: Old _____ New Steel _____ Plastic Other _____
Cemented from _____ ft. to _____ ft.
Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Gage _____
4 " 0 140 540
10) SCREEN:
Type PLASTIC
Perforated _____ Slotted
Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Slot Size _____
4 " 140 160 016

(Use reverse side if necessary)
7) COMPLETION (Check):
Straight wall Gravel packed _____ Other _____
Under reamed _____ Open Hole _____

11) WELL TESTS:
Was a pump test made? Yes _____ No If yes, by whom? _____
Yield: _____ gpm with _____ ft. drawdown after _____ hrs.
Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
Artesian flow _____ gpm
Temperature of water _____

8) WATER LEVEL:
Static level 40 ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____
Depth to pump bowls, cylinder, jet, etc., 120 ft. below land surface.

12) WATER QUALITY:
Was a chemical analysis made? Yes _____ No
Did any strata contain undesirable water? Yes _____ No
Type of water? _____ depth of strata _____

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.
NAME THOMAS ANDERS Water Well Drillers Registration No. 1226
(Type or Print)
ADDRESS PO Box 4 HUNTSVILLE TEX
(Street or RFD) (City) (State)
(Signed) Thomas Anders (Water Well Driller) _____ (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.


2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-CW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.



RECEIVED
JUN 12 1975
General Records
Texas Water Development Board

RECEIVED
JAN - 9 1975
TEXAS WATER
DEVELOPMENT BOARD

Send original copy by certified mail to the Texas Water Development Board P. O. Box 12386 Austin, Texas 78711

State of Texas

WATER WELL REPORT

For TWDB use only Well No. 60-27-2A Located on map 95 Received: 75 del

1) OWNER:
 Person having well drilled E. V. HARDING Address RT 2 HUNTSVILLE TEX
 (Name) (Street or RFD) (City) (State)
 Landowner " Address " "
 (Name) (Street or RFD) (City) (State)

2) LOCATION OF WELL:
 County WALKER 10 miles in W direction from HUNTSVILLE
 (N.E., S.W., etc.) (Town)

Locate by sketch map showing landmarks, roads, creeks, hiway number, etc.*

OVER North ↑
 (Use reverse side if necessary)

or Give legal location with distances and directions from adjacent sections or survey lines.

Labor _____ League _____
 Block _____ Survey _____
 Abstract No. _____
 (NW $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$ SE $\frac{1}{4}$) of Section _____

3) TYPE OF WORK (Check):
 New Well Deepening _____
 Reconditioning _____ Plugging _____
 4) PROPOSED USE (Check):
 Domestic Industrial _____ Municipal _____
 Irrigation _____ Test Well _____ Other _____
 5) TYPE OF WELL (Check):
 Rotary Driven _____ Dug _____
 Cable _____ Jetted _____ Bored _____

6) WELL LOG:
 Diameter of hole 6 3/4 in. Depth drilled 200 ft. Depth of completed well 200 ft. Date drilled MAR 15 73
 All measurements made from 0 ft. above ground level.

From (ft.)	To (ft.)	Description and color of formation material
<u>0-2</u>		<u>surface dirt</u>
<u>2-170</u>		<u>sandy clay</u>
<u>170-200</u>		<u>sand</u>

9) Casing:
 Type: Old _____ New Steel _____ Plastic _____ Other _____
 Cemented from 150 ft. to 170 ft.
 Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Gage _____
4 0 170 540

10) SCREEN:
 Type PLASTIC
 Perforated _____ Slotted
 Diameter (inches) _____ Setting From (ft.) _____ To (ft.) _____ Slot Size _____
2 3/4 170 200 2/16

7) COMPLETION (Check):
 Straight wall _____ Gravel packed _____ Other _____
 Under reamed Open Hole _____

11) WELL TESTS:
 Was a pump test made? Yes _____ No If yes, by whom? _____
 Yield: _____ gpm with _____ ft. drawdown after _____ hrs.
 Bailer test _____ gpm with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ gpm
 Temperature of water _____

8) WATER LEVEL:
 Static level 120 ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____
 Depth to pump bowls, cylinder, jet, etc., 160 ft. below land surface.

12) WATER QUALITY:
 Was a chemical analysis made? Yes _____ No
 Did any strata contain undesirable water? Yes _____ No _____
 Type of water? _____ depth of strata _____

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME THOMAS ANDERS Water Well Drillers Registration No. 1226
 (Type or Print)
 ADDRESS R.O. Box 4 HUNTSVILLE TEX
 (Street or RFD) (City) (State)
 (Signed) Thomas Anders (Water Well Driller) _____ (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

*Additional instructions on reverse side.

2) LOCATION OF WELL:

The sketch showing the well location must be as accurate as possible, showing landmarks, in sufficient detail so that the well may be plotted on a General Highway Map of the county in which the well is located.

Reference points from which distances are measured and directions given should be of a permanent nature (e.g. highway intersections, center of towns, river and creek bridges, railroad crossings). The distance and direction from the nearest town should always be indicated.

When giving a legal description include a sketch showing location of the well within the described area. e.g. survey abstract.

Information furnished in Section 2) of the TWDBE-CW-53 is very important. Unless the well can be accurately located on a map the value of the other data contained in the Report is greatly reduced.

