

ATTENTION OWNER: Confidentiality
Privilege Notice on reverse side
of Well Owner's copy

State of Texas
WELL REPORT

Texas Department of Licensing & Regulation
P.O. Box 12157
Austin, TX 78711
512-463-7880

1) OWNER Ken Owens ADDRESS FM 1375 W. New Waverly TX 77358
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL: County Walker FM 1375 W. New Waverly TX 77358 GRID # 60-27-9
(Street, RFD or other) (City) (State) (Zip) Long. _____ Lat. _____

3) TYPE OF WORK (Check): New Well Deepening Reconditioning Plugging
4) PROPOSED USE (Check): Monitor Environmental Soil Boding Domestic Industrial Irrigation Injection Public Supply De-watering Testwell
If Public Supply well, were plans submitted to the TNRCC? Yes No

6) WELL LOG: Date Drilling: Started 3/24 99 Completed 3/24 99
DIAMETER OF HOLE: Dia. (in.) 7" From (ft.) Surface To (ft.) 220'
7) DRILLING METHOD (Check): Driven Air Rotary Mud Rotary Bored Air Hammer Cable Tool Jetted Other _____

8) Borehole Completion (Check): Open Hole Straight Wall Underreamed Gravel Packed Other _____
If Gravel Packed give interval ... from _____ ft. to _____ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.) From	To	Gage Casting Screen
0	4	TOP SOIL SND						
4	11	BRN CL						
11	24	SND						
24	35	WHITE CL						
35	95	BLUE CL						
95	96	ROCK						
96	130	BLUE/RED CL	4	N	PVC	0	200	
130	165	LT BRN CL	4	N	PVC SLOTTED	200	220	.008
165	194	SND						
194	220	COURSE SND						

9) CEMENTING DATA: Cemented from 0 ft. to 100 ft. No. of sacks used 12
Casing left in well: _____ Cement/bentonite placed in well: _____ Sacks used: _____
Method used Pressure Tremmie
Cemented by Ballard Water Well
Distance to septic system field lines or other concentrated contamination 100+ ft.
Method of verification of above distance Measure

14) TYPE PUMP: Turbine Jet Submersible Cylinder Other _____
Depth to pump bowls, cylinder, jet, etc., 140 ft.

15) WELL TESTS: Type test: Pump Bailer Jetted Estimated
Yield: 50 gpm with 20 ft. drawdown after 2 Hrs.

16) WATER QUALITY: Did you knowingly penetrate any strata which contained undesirable constituents?
 Yes No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata _____
Was a chemical analysis made? Yes No

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

Ballard Water Well (Type or print)
ADDRESS P.O. Box 970
(Signed) Charles A. Ballard (Licensed Well Driller)
WELL DRILLER'S LICENSE NO. 2384WI Willis (City)
(Signed) _____
APR 17 2000 (State) (Zip) TX 77378
(Registered Driller Trainee)

