

ATTENTION OWNER: Confidentiality  
Privilege Notice on reverse side  
of Well Owner's copy (pink)

## State of Texas WELL REPORT

Texas Department of Licensing &  
Regulation  
P.O. Box 12157  
Austin, TX 78711  
512-463-7880

1) OWNER Lipar Group Inc. ADDRESS  Hwy 1488 Hempstead, Tx.  
(Name) (Street or RFD) (City) (State) (Zip)

2) ADDRESS OF WELL'S LOCATION: Same as above Long. \_\_\_\_\_ Lat. \_\_\_\_\_  
County Waller (Street, RFD or other) (City) (State) (Zip) Grid # 60-50-5

3) TYPE OF WORK (Check):  
 New Well  Deepening  
 Reconditioning  Plugging

4) PROPOSED USE (Check):  Monitor  Environmental Soil Boring  Domestic  
 Industrial  Irrigation  Injection  Public Supply  De-watering  Testwell  
If Public Supply well, were plans submitted to the TNRCC?  Yes  No

6) WELL LOG:

Date Drilling: Started <u>Nov 25 19 98</u> Completed <u>Nov 17 19 98</u>	DIAMETER OF HOLE		
	Dia. (in.)	From (ft.)	To (ft.)
	5	Surface	250

7) DRILLING METHOD (Check):  Driven  
 Air Rotary  Mud Rotary  Bored  
 Air Hammer  Cable Tool  Jetted  
 Other \_\_\_\_\_

From (ft.)	To (ft.)	Description and color of formation material
0-35		Clay & sand
35-45		Sand
45-56		Clay
56-60		Sand
60-166		Clay
166-170		Rock
170-225		Clay
225-250		Sand.

(Use reverse side of Well Owner's copy, if necessary)

8) Borehole Completion (Check):  Open Hole  Straight Wall  
 Underreamed  Gravel Packed  Other \_\_\_\_\_  
If Gravel Packed give interval from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)		Gage Casting Screen
			From	To	
2	N	PVC.	0	230	40
8	N	P.V.C. Jacos	230	250	.06

13)  Well plugged within 48 hours

Casing left in well:		Cement/bentonite placed in well:		Sacks used:
From (ft)	To (ft)	From (ft)	To (ft)	

9) CEMENTING DATA

Cemented from 0 ft. to 10 ft. No. of sacks used 5  
ft. to \_\_\_\_\_ ft. No. of sacks used \_\_\_\_\_

Method used Hand Mix  
Cemented by CAWW.

Distance to septic system field lines or other concentrated contamination 100 ft.  
Method of verification of above distance owner, sealed tank

14) TYPE PUMP:

Turbine  Jet  Submersible  Cylinder  
 Other \_\_\_\_\_  
Depth to pump bowls, cylinder, jet, etc., 120 ft.

10) SURFACE COMPLETION

Specified Surface Slab Installed  
 Specified Steel Sleeve Installed  
 Pitless Adapter Used  
 Approved Alternative Procedure Used

15) WELL TESTS:

Type test:  Pump  Bailer  Jetted  Estimated  
Yield: 3 gpm with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

11) WATER LEVEL:

Static level 100 ft. below land surface Date Nov 17, 98  
Artesian flow \_\_\_\_\_ gpm. Date \_\_\_\_\_

16) WATER QUALITY:

Did you knowingly penetrate any strata which contained undesirable constituents?  
 Yes  No If yes, submit "REPORT OF UNDESIRABLE WATER"  
Type of water? Potable Depth of strata 25'  
Was a chemical analysis made?  Yes  No

12) PACKERS:

Type	Depth
<u>Formation</u>	<u>220'</u>

I certify that I drilled this well (or the well was drilled under my direct supervision) and that each and all of the statements herein are true and correct. I understand that failure to complete items 1 thru 16 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME COASTAL WATER WELLS (Type or print)

ADDRESS P.O. Box 745 (Street or RFD) Porter (City) TX (State) 77365 (Zip)

(Signed) J. L. Gehnel (Licensed Well Driller) \_\_\_\_\_ (Registered Driller Trainee)

FILE #

SEC #

FEB 26 1999

JAN 25 1999

WELL DRILLER'S LICENSE NO. 812

COMMENTS

Please attach electric log, chemical analysis, and other pertinent information, if available.

